



2018 Annual Water Quality Report

Suck Creek
PWS ID: TN0000909

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda.
This report contains important information about your drinking water. Have someone translate it for you if needed.

A Message from the Tennessee American Water President

To Our Valued Customer:

Tennessee American Water has been providing water to Chattanooga and the surrounding area for 130 years. Each year, we provide you with our Annual Water Quality Report. Like so many years prior, we are pleased to report that your water meets or surpasses all state and federal water quality regulations.

We know how important water is to your daily life. We appreciate that you expect your drinking water to be clean, safe, reliable, and affordable. This expectation motivates our employees to monitor and test every stage of the water treatment process, around-the-clock, to ensure your drinking water meets all quality standards. Our team of employees is proud of this commitment to you, as well as our mission to “Keep Life Flowing”.



We are committed to maintaining the hundreds of miles of pipes, tanks, pump stations, treatment equipment and more. Each year we invest approximately \$20 million in the community’s drinking water system. We participate in the Partnership for Safe Drinking Water, a voluntary program adopting more stringent performance goals than those required by federal and state drinking water standards.

At Tennessee American Water, our customers are our top priority. We are committed to providing you with the highest quality drinking water and services possible. Please take the time to review this report. It provides details about the source and quality of your drinking water, using the data from water quality testing conducted from your local water system January through December 2018

Thanks for allowing us to serve you.

Sincerely,

Valoria V. Armstrong
President, Tennessee American Water



American Water Works Company, Inc., together with its subsidiaries, is referred to as American Water. “Tennessee American Water” and the star logo are the registered trademarks of American Water Works Company, Inc. All rights reserved.

About American Water

With a history dating back to 1886, American Water is the largest and most geographically diverse U.S. publicly traded water and wastewater utility company. The company employs more than 7,100 dedicated professionals who provide regulated and market-based drinking water, wastewater and other related services to more than 14 million people in 46 states and Ontario, Canada. American Water provides safe, clean, affordable and reliable water services to our customers to make sure we keep their lives flowing. For more information, visit amwater.com and follow American Water on [Twitter](#), [Facebook](#) and [LinkedIn](#).

About Tennessee American Water

Tennessee American Water, a subsidiary of American Water (NYSE: AWK), is the largest investor-owned water utility in the state, providing high-quality and reliable water services to approximately 390,000 people in Tennessee and northern Georgia.

Environmental Stewardship

Water is one of the earth's most precious natural resources. Protecting the environment helps to ensure adequate water supply for generations and we believe that all of us play a part. Our efforts include student education, community partnerships and our environmental grant program.

We believe that all of us play a part in protecting our water and can do so through a variety of activities.

- Read this report
- Take a tour of the Tennessee American Water Plant
- Participate in Drug Take Back (more information below)
- Reduce plastic use to protect aquatic life. Choose reusable water bottles, straws and shopping bags.
- Install & properly maintain backflow prevention devices if you have an irrigation system (more information below)
- Practice water conservation by being "Water Smart" (more information below)

Source Water Information

Your water, which is ground water, comes from a Cambrian-Ordovician carbonate the type aquifer from two water supply wells located on Suck Creek Mountain. To supplement your supply, we also purchase water from Lone Oak Utility District whose original source is Hixson Utility District. Hixson Utility District draws ground water from a Cambrian-Ordovician carbonate type aquifer in the Chickamauga watershed. Our goal is to protect our water from contamination and we are working with the state to determine the vulnerability of our water source to potential contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for the untreated water sources serving this water system. The SWAP Report assesses the susceptibility of untreated water sources to potential contamination.

To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible (high), moderately susceptible (moderate) or slightly susceptible (low) based on geologic factors and human activities in the vicinity of the water source. Tennessee American Water sources are rated as reasonably susceptible to potential contamination.


An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at <https://www.tn.gov/environment/program-areas/wr-water-resources/water-quality/source-water-assessment.html> or contact TDEC EAC at 1-888-891-8332 (1-888-891-TDEC) to obtain copies of specific assessments. Tennessee American Water can also be contacted at 1-866-736-6420 to obtain a copy of the source water assessment specifically for our company.

Think before you flush! Drug Disposal Program

Flushing unused or expired medicines can be harmful to your drinking water. Properly disposing of unused or expired medication helps protect you and the environment. Keep medications out of Tennessee's waterways by disposing in one of our permanent pharmaceutical take back bins. There are nearly 100 take back bins located across the state, to find a convenient location please visit:

https://www.tn.gov/content/dam/tn/environment/sustainable-practices/documents/opsp_pharm_take-back-locations-updated.pdf. Included are the following local sites:

Chattanooga Police Department (9am-4pm, 3204 Amnicola Hwy, Property Room), Hamilton County Sherriff's Department (9am-4pm, 2 locations – 6233 Dayton Blvd and 8395 Hickory Valley Road), Red Bank Police Department (9am-4pm, 3117 Dayton Blvd), East Ridge Police Department (7am-4pm, 4214 Ringgold Road), Signal Mountain Police Department (9am-4pm, 1111 Ridgeway Drive), Bradley County Sherriff's Office (2290 Blythe), Cleveland Police Department (100 Church Street NE), and Whitwell City Hall (8:30am-5pm, 13671 Hwy 28).



Area wide Drug Take Back day is April 27, 2019. Look for more information on Facebook, Twitter or our website.

Protecting our Vital Wellhead Area

Suck Creek Water System recognizes its responsibility to protect its wellhead area. No chemicals other than water treatment chemicals will be stored within 750 feet of the wellhead, and the Utility will not apply chemicals on property it owns within 100 feet of the water sources. Applicable signs will be posted. Further, activity within our wellhead management area will be continuously monitored; all discrepancies will be reported to the Tennessee Division of Water Supply. The Wellhead Protection Plan is available for inspection at 109 Wiehl Street, Chattanooga, TN 37403. Please call Kitty Vaughn at 423-771-4749 between 7 AM and 4 PM to schedule an appointment.

The primary sources of your drinking water are wells located atop Walden's Ridge within the Suck Creek community. This wellhead area is also the same area through which contaminants are likely to travel and reach your source of supply. The water in those wells comes from groundwater which originates as rainwater and passes through the ground into the water table or well recharge area, known as the aquifer.

Contamination from natural sources or activities by customers can permanently damage the aquifer. In general, groundwater contamination can stem from the misuse or improper disposal of liquid or solid wastes, septic tank failures, exterminators' products, illegal dumping or abandonment of chemicals, or the accidental spilling of chemicals. For example, one gallon of gasoline can render one million gallons of groundwater undrinkable. Special precautions should always be used in disposal of any chemical, which should never be dumped on the ground.

Protection of our groundwater is vitally important as it helps to provide safe and reliable drinking water for everyone. The best way to protect your drinking water is to ensure it does not become contaminated. That means you should know that anything you pour on the ground or down the drain can affect the quality of your drinking water. For more information on groundwater protection and how you can be a part of protecting this vital resource please visit EPA's website at: <http://www.epa.gov/sourcewaterprotection>.

Community Participation

If you are interested in learning more about water quality at Tennessee American Water, please call us at (423) 771-4798. Our normal office hours are 8 a.m. to 5 p.m., Monday – Friday. We also encourage you to stay involved by:

- Reading the information provided in bill inserts and special mailings.
- Contacting the company directly with questions or to discuss issues and reviewing information on our website tennesseeamwater.com
- Attending events conducted by the company.
- Responding to survey requests.
- Like us on Facebook www.facebook.com/tnamwater
- Follow us on Twitter @tnamwater



How to Contact Us

For more information about this report, or for any questions relating to your drinking water, please call Kitty Vaughn, Water Quality & Environmental Compliance Supervisor, or the Water Quality Lab at (423) 771-4749. For questions about your water bill, please call our Customer Service Center at (866) 736-6420.

Share This Report

Landlords, businesses, schools, hospitals and other groups are encouraged to share this important water quality information with water users at their location who are not customers of Tennessee American Water. Additional copies of this report are available by contacting us at (423) 771-4749.

Water System Security

Following the events of September 11th, 2001, we realize that our customers are concerned about the security of their drinking water. We urge the public to report any suspicious activities at any utility facilities, including treatment plants, tanks, fire hydrants, etc. to 1-866-736-6420.

Cryptosporidium

Cryptosporidium is a microbial pathogen found in surface water throughout the US. Although *Cryptosporidium* can be removed through commonly-used filtration methods, US EPA issued a rule in January 2006 that requires systems with higher *Cryptosporidium* levels in their source water to provide additional treatment. Tennessee American Water monitored for *Cryptosporidium* and based upon our results, no additional treatment will be required by this US EPA regulation.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the EPA's Safe Drinking Water Hotline (800) 426-4791.

Water Information Sources

- Tennessee American Water: www.tennesseeamwater.com
- Tennessee Department of Environment and Conservation: www.tn.gov/environment
- United States Environmental Protection Agency: www.epa.gov/safewater
- Safe Drinking Water Hotline: (800) 426-4791
- American Water Works Association: www.awwa.org

Remember to "Be Water Smart" Wise Water Use Tips For Inside Your Home:

- Fix leaking faucets, pipes, toilets, etc
- Replace old fixtures; install water-saving devices in faucets, toilets and appliances
- Wash only full loads of laundry
- Do not use the toilet for trash disposal
- Take shorter showers
- Do not leave water running while shaving or brushing teeth
- Soak dishes before washing
- Run the dishwasher only when full
- Use mulch around plants and shrubs
- Repair leaks in faucets and hoses
- Use water-saving nozzles

What's it take to bring water to your tap?
 Miles of pipeline, constantly renewed.
 Testing and treating it. People working
 day and night to keep it flowing.
 Water: Quality, care and value delivered in
 every drop.

WE CARE ABOUT WATER. IT'S WHAT WE DO.
 FIND OUT WHY YOU SHOULD, TOO, at amwater.com

AMERICAN WATER

Wise Water Use Tips for Outside Your Home:

American Water Works Company, Inc., together with its subsidiaries, is referred to as American Water. "Tennessee American Water" and the star logo are the registered trademarks of American Water Works Company, Inc. All rights reserved.

Protecting Our Water Supply – Backflow Prevention

Tennessee American Water has a backflow prevention program that ensures proper installation and maintenance of thousands of backflow prevention devices throughout our system. These devices ensure hazards originating on the customers' properties and from temporary connections do not impair or alter the quality of water in our distribution system. For more information about Tennessee American Water's backflow prevention program, please visit our website at www.tennesseeamwater.com, or contact our Cross Connection Control Specialists at tawc.crossconnection@amwater.com or (423) 771-4701.

Substances Expected to be in Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by call the U.S. Environmental Protection Agency's Safe Drinking Water Hotline (800) 426-4791.

In order to ensure that tap water is safe to drink, U.S. Environmental Protection Agency (EPA) and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Tennessee American Water's water treatment processes are designed to reduce any such substances to levels well below any health concern.

The source of drinking water (both tap water and bottled water) includes rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial Contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic Contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and Herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- **Radioactive Contaminants**, which can be naturally occurring or may be the result of oil and gas production and mining activities.

For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

How to Read the Water Quality Data Table

Tennessee American Water conducts extensive monitoring to ensure that your water meets all water quality standards. The results of our monitoring are reported in the following tables. While most monitoring was conducted in 2018, certain substances are monitored less than once per year because the levels do not change frequently.

Starting with a **Substance**, read across. **Year Sampled** is usually in 2018 or year prior. **MCL** shows the highest level of substance (contaminant) allowed. **MCLG** is the goal level for that substance (this may be lower than what is allowed). **Amount Detected** represents the measured amount (less is better). **Range** tells the highest and lowest amounts measured. A **Yes** under **Compliance Achieved** means that the government requirement was met. **Typical Source** tells where the substance usually originates.

Water Quality Statement

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

We are pleased to report that during the past year, the water delivered to your home or business met or exceeded all state and federal drinking water requirements. For your information, we have compiled a list in the table, showing what substances were detected in your drinking water during 2018. Although all of the substances listed below surpasses or meets all federal and state water quality regulations, we feel it is important that you know exactly what was detected and how much of the substance was present in the water.

Table Definitions and Abbreviations

- **Action Level:** The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.
- **BDL:** Below Detection Limit
- **MCL (Maximum Contaminant Level):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **MCLG (Maximum Contaminant Level Goal):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MRDL (Maximum Residual Disinfectant Level):** The highest level of disinfectant routinely allowed in drinking water. Addition of a disinfectant is necessary for control of microbial contaminants.
- **MRDLG (Maximum Residual Disinfectant Level Goal):** The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- **NA:** Not applicable.
- **NTU – Nephelometric Turbidity Units:** Turbidity is a measure of the clarity of the water. Turbidity in excess of 5 NTUs is just noticeable to the average person.
- **pCi/L (picocuries per liter):** Measurement of the natural rate of disintegration of radioactive contaminants in water (also beta particles).
- **ppm (parts per million) or mg/L (milligrams per liter):** One part substance per million parts water, or milligrams per liter, explained in terms of money as one penny in \$10,000.
- **ppb (parts per billion) or µg/L (micrograms per liter):** One part substance per billion parts water, or micrograms per liter, explained in terms of money as one penny in \$10,000,000.
- **TT (Treatment Technique):** A required process intended to reduce the level of a contaminant in drinking water.

Tennessee American Water – Suck Creek - 2018 WATER QUALITY DATA (PWS ID # TN0000909)

Regulated Substances

Substance (units)	Year Sampled	MCLG	MCL	Amount Detected	Range	Compliance Achieved	Typical Source
E.Coli ¹	January 2018 – December 2018	0	TT	0	0	Yes	Naturally present in the environment
Turbidity ² (NTU)	2018	NA	TT	0.057	0.029 – 0.065	Yes	Soil runoff
Chlorine ³ (ppm)	2018	MRDLG = 4	MRDL = 4	1.13 (avg) 1.96 (max)	0.31 – 1.96	Yes	Water additive used to control microbes
Fluoride (ppm)	2018	4	4	0.73 (avg)	0.62 – 0.82	Yes	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate (ppm)	2018	10	10	0.03	0.02 - 0.03	Yes	Runoff from fertilizer use; Leaching from septic tanks; Sewage; Erosion of natural deposits.
Xylene (ppm) ⁴	2018	10	10	BDL	BDL	Yes	Discharge from petroleum factories.
Ethyl Benzene (ppb) ⁴	2018	700	700	BDL	BDL	Yes	Discharge from petroleum factories. Discharge from chemical factories
Sodium (ppm)	2018	NA	NA	27.3	23.6 – 30.9	NA	Erosion of natural deposits; Used in water treatment

¹ System is in compliance for E.Coli MCL unless it has E.coli positive repeat sample for total coliform positive routine sample, total coliform positive repeat sample for an E.coli positive routine sample, system fails to collect all required routine samples, or system fails to test all positive total coliform samples for E.Coli.

² Turbidity is a measure of the cloudiness of the water. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system. During 2018, 100% of all samples taken to measure turbidity met water quality standard of less than 0.3 NTU.

³ Chlorine levels as measured in the distribution system.

⁴ Xylene and Ethyl Benzene were detected at low levels after painting the Suck Creek tank in 2013. Results from follow up testing in 2018 were below the detection level.

Disinfection By-Products⁵

Substance (units)	Year Sampled	MCLG	MCL	Amount Detected	Range	Compliance Achieved	Typical Source	Health Effects Language
Total Trihalomethanes (TTHMs) (ppb)	2018	NA	80	25.5	7.9-25.5	Yes	By-product of drinking water disinfection	Some people who drink water containing trihalomethanes in excess of the MCL over many years could have problems with their liver, kidney, or central nervous systems and may have an increased risk of getting cancer.
Haloacetic Acids (HAA5) (ppb)	2018	NA	60	4.7	1.7-4.7	Yes	By-product of drinking water disinfection	NA

⁵ Disinfection by-products value reported for “amount detected” is the maximum locational running annual average. The range includes all samples analyzed during 2018.

Tap water samples were collected for lead and copper analyses from 10 households. None of the 10 homes exceeded the action levels.

Substance (units)	Year Sampled	Action Level	MCLG	Amount Detected (90th %tile)	Range of Detections	Compliance Achieved	Typical Source
Copper (ppm)	2018	1.3	1.3	0.163	BDL - 0.164	Yes	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	2018	15	0	BDL	All samples BDL (below detection level)	Yes	Corrosion of household plumbing systems; Erosion of natural deposits

Lead in Drinking Water: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We take steps to reduce the potential for lead to leach from your pipes into the water. This is accomplished by adding a corrosion inhibitor to the water leaving our treatment facilities. There are steps that you can take to reduce your household’s exposure to lead in drinking water. Tennessee American Water – Suck Creek is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://www.epa.gov/safewater/lead>

Lone Oak Utility District 2018 WATER QUALITY DATA (PWS ID # TN0008228)

The chart below is the water quality information from Lone Oak Utility District. This information is being provided due to Suck Creek obtaining water for their customers as needed from Lone Oak Utility District (LOUD). Water from LOUD was produced by Hixson Utility District. The chart below is the 2018 water quality information from LOUD.

Regulated Substances

Substance (units)	Year Sampled	MCLG	MCL	Amount Detected	Range	Compliance Achieved	Typical Source
E.Coli ¹	January 2018 – December 2018	0	TT	0	0	Yes	Naturally present in the environment
Chlorine ² (ppm)	2018	MRDLG = 4	MRDL = 4	0.70 (avg)	0.30 – 0.90	Yes	Water additive used to control microbes
Total Trihalomethanes (TTHMs) (ppb)	2018	NA	80	15.2		Yes	By-product of drinking water disinfection
Haloacetic Acids (HAA5) (ppb)	2018	NA	60	ND		Yes	By-product of drinking water disinfection

¹ System is in compliance for E.Coli MCL unless it has E.coli positive repeat sample for total coliform positive routine sample, total coliform positive repeat sample for an E.coli positive routine sample, system fails to collect all required routine samples, or system fails to test all positive total coliform samples for E.Coli.

² Chlorine levels as measured in the LOUD distribution system.

Hixson Utility District 2018 WATER QUALITY DATA (PWS ID # TN0000303)

The chart below is the water quality information from Hixson Utility District. This information is being provided due to Suck Creek obtaining water for their customers as needed from Lone Oak Utility District (LOUD). Water from LOUD was produced by Hixson Utility District. The chart below is the 2018 water quality information from Hixson Utility District.

Regulated Substances

Substance (units)	Year Sampled	MCLG	MCL	Amount Detected	Range	Compliance Achieved	Typical Source
Turbidity ¹ (NTU)	2018	NA	TT	0.9	0.1 – 0.9	Yes	Soil runoff
Alpha Emitters (pCi/L)	2014	0	15	1.4	1.3 – 1.4	Yes	Erosion of natural deposits
Combined Radium (pCi/L)	2014	0	5	0.96	BDL – 0.96	Yes	Erosion of natural deposits
Copper ² (ppm)	2017	1.3	AL = 1.3	90 th % = 0.58	0.17 – 0.60	Yes	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead ² (ppb)	2017	0	AL = 15	90 th % = 1.5	BDL – 3.0	Yes	Corrosion of household plumbing systems; Erosion of natural deposits
Fluoride (ppm)	2018	4	4	1.3	0.6 – 1.3	Yes	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate (ppm)	2018	10	10	0.801	ND – 0.801	Yes	Runoff from fertilizer use; Leaching from septic tanks; Sewage; Erosion of natural deposits
Sodium (ppm)	2018	NA	NA	1.72	1.54– 1.72	NA	Erosion of natural deposits; Used in water treatment

¹ Turbidity is a measure of the cloudiness of the water. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system. During 2018, no daily reading exceeded 1 NTU. No monthly averages exceeded 1 NTU.

² None of the households tested by Hixson Utility District for lead and copper exceeded the action level.