

METER TEST RESULTS – METER ACCURATE

California-American Water Company

P.O. Box 578, Alton IL 62002
1-800-794-7350

05/13/2002

Dear Customer:

On Sunday, May 5, 2002, your water meter was tested at both an intermediate and a full flow of water.

The testing indicated that your meter was registering 100.0 percent at the full flow and 100.0 percent at the intermediate flow. According to regulations set by the California Public Utilities Commission, a meter is considered operating in a satisfactory manner if it records water use between 98.5 percent and 101.5 percent of actual usage. Therefore, this meter's registration is considered accurate.

If you have any concerns regarding this test, please call out 24-hour customer service number at 1-800-794-7350, 24 hours a day, 7 days a week. Thank you.

Sincerely,

(TO BE INSERTED BY UTILITY)

ADVICE LETTER NO. 566

ISSUED BY

D. P. STEPHENSON

NAME

(TO BE INSERTED BY C.P.U.C.)

DATE FILED JUN 18 2002

EFFECTIVE JUL 22 2002

DECISION NO. _____

DIRECTOR - RATES & REVENUES

TITLE

RESOLUTION NO. _____