


2008 Annual Water Quality Report



Granite City
PWSID: IL1195030

Este informe contiene información muy importante sobre su agua de beber.
Tradúscalo ó hable con alguien que lo entienda bien.

A Message from Illinois American Water President

As a trusted leader in the industry, Illinois American Water places a strong emphasis on sharing information about the quality of the water we provide with our customers.

One way we do this is by reporting to you annually the results of our tests on the water we deliver to your home. Please review this Consumer Confidence Report (CCR), which outlines information applicable to your local water system for testing completed through December, 2008. You'll find that we provide water that surpasses or meets all federal and state water quality regulations. In fact, we often address regulations well before they go into effect.

Just as important, Illinois American Water makes the necessary investments to maintain and upgrade its facilities, so that we can deliver quality water directly to your tap 24 hours a day, seven days a week.

Our customers are our top priority, and we are committed to providing them with the highest quality drinking water and service possible now and in the years to come. In addition to this written report, you can view information about Illinois American Water and your water system on our website www.illinoisamwater.com. For more information or for more copies of this report relating to your drinking water, please contact Sarah Boyd at 618-874-2408 or at sarah.boyd@amwater.com.

Sincerely,

*Karla Olson Teasley
President of Illinois American Water*

What is a Water Quality Report?

Illinois American Water issues a report annually describing the quality of your drinking water in compliance with state and United States Environmental Protection Agency (USEPA) regulations. The purpose of this report is to increase understanding of drinking water and raise awareness of the need to protect your drinking water sources.

At our state-of-the-art research laboratory in Belleville, Illinois, we conduct over 57,000 tests per year, checking drinking water quality at every stage of the water treatment and delivery process. In 2008, we conducted tests for hundreds of contaminants, all of which were federal and state maximum allowable levels. This report provides an overview of last year's (2008) water quality. It includes details about your water source and what it contains.

Source Water Information

The Granite City Water Treatment Facility draws surface water for treatment from the Mississippi River. The Mississippi River is subject to a variety of influences including agricultural, municipal, and industrial activities. Farm chemicals may be seasonally elevated in the river. Extensive monitoring and treatment ensure high-quality water service regardless of variations in the source water. The Illinois Environmental Protection Agency (IEPA) has completed a source water assessment for the Granite City system and a copy is available.

Partnership for Safe Drinking Water Program

In 2007 Illinois American Water's Granite City District was awarded the prestigious "Five-Year Director's Award" under the Partnership for Safe Water program administered by the USEPA and other water related organizations. The award honors water utilities for achieving operational excellence, by voluntarily optimizing their treatment facility operations and adopting more stringent performance goals than those required by federal and state drinking water standards. We are proud to report that we have maintained those standards throughout 2008. Only a small percentage of facilities in the United States have received the Five-Year Partnership Award.



About American Water

Founded in 1886, American Water is the largest investor-owned U.S. water and wastewater utility company. With headquarters in Voorhees, N.J., the company employs more than 7,000 dedicated professionals who provide drinking water, wastewater and other related services to approximately 15 million people in 32 states and Ontario, Canada.

Illinois American Water, a wholly owned subsidiary of American Water (NYSE:AWK), is the largest investor-owned water utility in the state, providing high-quality and reliable water and/or wastewater services to more than 1.2 million people. We own and maintain approximately 4,393 miles of main, 284,743 water meters, and 28,317 hydrants in over 100 Illinois communities, from Cairo to the Chicago suburbs.

Environmental Stewardship

Illinois American Water is committed to protecting the environment and our water resources to maintain water supply for future generations. A few of our community programs include:

Pharmaceutical disposal programs: As a member of the IEPA's Medication Education Disposal Solution program, Illinois American Water collaborates with environmentalists, pharmacists, water utilities and healthcare providers to develop local pharmaceutical disposal programs. The group also works together to promote proper pharmaceutical disposal practices. To learn more or to find a disposal location near you, please visit <http://www.epa.state.il.us/medication-disposal/>.

Water conservation: Illinois American Water offers free National Theatre for Children programs for elementary schools to teach students about wise use of our water resources.

Environmental grant program: Our nation-wide environmental grant program presented 18 grants in 2008, totaling more than \$100,000 for programs that improve, restore and protect our watersheds.

Questions?

To learn more about water quality, visit our website at: www.illinoisamwater.com. For questions or copies contact Sarah Boyd, water quality supervisor, at sarah.boyd@amwater.com or 618-874-2408.

Water Information Sources

- **Illinois American Water**
www.illinoisamwater.com
- **United States Environmental Protection Agency (USEPA)**
www.epa.gov/safewater
- **Safe Drinking Water Hotline:** 800-426-4791
- **Illinois Environmental Protection Agency (IEPA)**
www.epa.state.il.us
- **Surf Your Watershed**
Locate your watershed and a host of information.
<http://cfpub.epa.gov/surf/locate/index.cfm>
- **Envirofacts**
Access to U.S. environmental data.
www.epa.gov/enviro

Substances Expected to be in Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it can acquire naturally occurring minerals, in some cases, radioactive material, and substances resulting from the presence of animals or from human activity.

Substances that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife. Turbidity measurement can be an effective tool to determine removal efficiency of particles, some of which may include microbial contaminants. Turbidity is a measurement of the cloudiness in the water caused by suspended particles. We continuously monitor turbidity because it is a good indicator of water quality and the effectiveness of our filtration system.

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, may also come from gas stations, urban storm water runoff, and septic systems.

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

To ensure that tap water is of high quality, USEPA prescribes regulations limiting the amount of certain substances in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Illinois American Water's advanced water treatment processes are designed to reduce any such substances to levels well below any health concern.

A Message For People With Severely Weakened Immune Systems

Cryptosporidium is a protozoan found in untreated surface waters throughout the United States (the organism is generally not present in a ground water source). Although filtration removes Cryptosporidium, the most commonly used filtration methods cannot guarantee 100% removal. Ingestion of Cryptosporidium may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, people with severely weakened immune systems have a risk of developing life-threatening illness. We encourage such people to consult their doctors regarding appropriate precautions to take to avoid infection. Cryptosporidium must be ingested to cause disease, and it is spread through means other than drinking water.

Cryptosporidium is a protozoan found in surface waters throughout the US. Although Cryptosporidium can be removed through most commonly-used filtration methods, USEPA issued a new rule in January 2006 that requires systems with higher Cryptosporidium levels in their source water to provide additional treatment. In anticipation of this upcoming rule, Illinois American Water – Granite City monitored for Cryptosporidium in its raw water in 2003 – 2005. Based on the results of our Cryptosporidium monitoring, no additional treatment will be required by the new USEPA regulation.

Important Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (800) 426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

USEPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791.

LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Illinois American Water is responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

How to Read the Data Tables

Illinois American Water conducts extensive monitoring to ensure that your water meets all water quality standards. The results of our monitoring are reported in the data tables. While most monitoring was conducted in 2008, certain substances are monitored less than once per year because the levels do not change frequently. For help with interpreting these tables, see the "Table Definitions" section and footnotes.

Table Definitions and Abbreviations

- **Action Level:** The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.
- **Amount Detected:** Unless otherwise noted in the footnotes, an average of all sample results for the year, or results from a single sample if only one was collected. If multiple entry points exist, the data from the entry point with the highest value is reported.
- **Compliance Achieved:** Indicates that the levels found were all within the allowable levels as determined by the EPA.
- **MCL (Maximum Contaminant Level):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **MCLG (Maximum Contaminant Level Goal):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MRDL (Maximum Residual Disinfectant Level):** The highest level of disinfectant routinely allowed in drinking water. Addition of a disinfectant is necessary for control of microbial contaminants.
- **MRDLG (Maximum Residual Disinfectant Level Goal):** The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- **NA:** Not applicable.
- **ND:** Not detected.
- **NTU - Nephelometric Turbidity Units:** Measurement of the clarity, or turbidity, of water.
- **pCi/L (picocuries per liter):** Measurement of the natural rate of disintegration of radioactive contaminants in water (also beta particles).
- **ppm (parts per million):** One part substance per million parts water, or milligrams per liter.
- **ppb (parts per billion):** One part substance per billion parts water, or micrograms per liter.
- **Range of Detections:** The range of individual sample results, from lowest to highest, that were collected during the sample period.
- **Removal Factor:** Actual percent TOC removal divided by required percent TOC removal.
- **S:** Single Sample.
- **TT (Treatment Technique):** A required process intended to reduce the level of a contaminant in drinking water.
- **≥:** Greater than or equal to.
- **% < 0.3 NTU:** Percent of all samples less than 0.3 NTU.

2008 Water Quality Information

We are pleased to report that during the past year, the water delivered to your home or business complied with, or was better than, all state and federal drinking water requirements. For your information, we have compiled a table showing what substances were detected in your drinking water during 2008. Although all of the substances listed are under the Maximum Contaminant Level (MCL) set by the USEPA, we feel it is important that you know exactly what was detected and how much of the substance was present in the water.

Regulated Substances (Measured in the water leaving the treatment facility)								
Substance (units)	Year Sampled	MCLG	MCL	Amount Detected	Range of Detections	Compliance Achieved	Typical Source	
Arsenic (ppb)	2008	0	10	2	S	Yes	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes	
Atrazine (ppb)	2008	3	3	0.3	ND - 1.3	Yes	Runoff from herbicide used on row crops	
Barium (ppm)	2008	2	2	0.075	S	Yes	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	
Fluoride (ppm) ¹	2008	4	4	1.1	1.0 - 1.1	Yes	Water additive that promotes strong teeth	
Nitrate (ppm) ²	2008	10	10	5.2	2.4 - 5.2	Yes	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	
Selenium (ppb)	2008	50	50	2	S	Yes	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines	
Other Compounds (Measured in the distribution system or in the water leaving the treatment facility)								
Substance (units)	Year Sampled	MCLG/MRDLG	MCL/MRDL	Amount Detected	Range of Detections	Compliance Achieved	Typical Source	
THMs [Total trihalomethanes] (ppb)	2008	NA	80	25.0	13.7 - 42.5	Yes	By-product of drinking water chlorination	
HAA5 [Haloacetic acids] (ppb)	2008	NA	60	26.1	8.5 - 35.5	Yes	By-product of drinking water chlorination	
Chloramines (ppm) ³	2008	4	4	2.8	1.4 - 3.2	Yes	Water additive used to control microbes	
TOC [Total organic carbon] (removal factor) ⁴	2008	NA	TT Removal ≥ 1.0	1.3	1.0 - 1.5	Yes	Naturally present in the environment	
Turbidity ⁵ - (Measured in water leaving the treatment facility)								
Substance (units)	Year Sampled	MCLG	MCL	Amount Detected	Range of Detections	Compliance Achieved	Typical Source	
Turbidity (NTU) (% < 0.3 NTU)	2008	NA	TT	100%	100% - 100%	Yes	Soil runoff	
Turbidity (NTU)	2008	NA	TT = 1 NTU max	0.16	NA	Yes	Soil runoff	
Lead and Copper ⁶ (Collected at customers' taps)								
Substance (units)	Year Sampled	MCLG	Action Level	90th Percentile	Number of Samples Collected	Number of Samples Above Action Level	Compliance Achieved	Typical Source
Copper (ppm)	2008	1.3	1.3	0.087	31	0	Yes	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	2008	0	15	2	31	0	Yes	Corrosion of household plumbing systems; Erosion of natural deposits
State Regulated Substances								
Substance (units)	Year Sampled	MCLG	MCL	Amount Detected	Range of Detections	Compliance Achieved	Typical Source	
Manganese (ppb) ⁷	2008	NA	150	19	S	Yes	Erosion of naturally occurring deposits	
Sodium (ppm) ⁸	2008	NA	NA	24	S	Yes	Erosion of naturally occurring deposits; By-product of home water softening	
Zinc (ppb) ⁹	2008	NA	5000	263	S	Yes	Naturally occurring; Water treatment additive	
Unregulated Substances ¹⁰								
Substance (units)	Year Sampled	Amount Detected	Range of Detections	Typical Source				
Sulfate (ppm)	2008	46.4	S	Erosion of naturally occurring deposits				

¹ Fluoride is added to the water supply to help promote strong teeth. The Illinois Department of Public Health recommends an optimal fluoride level of 0.9 mg/L to 1.2 mg/L.

² The value in the "amount detected" column is the maximum detected for the year. Nitrate in drinking water at levels above 10 ppm is a health risk for infants less than 6 months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice from your health care provider.

³ Chlorine and chloramines are disinfecting agents added to control microbes that otherwise could cause waterborne diseases or other water quality concerns. Most water systems in Illinois are required by law to add either chlorine or chloramines. Levels well in excess of the MRDL could cause irritation of the eyes or nose in some people. The values reported reflect multiple locations in the service area. At the Granite City facility, chloramines are used the majority of the year. Chloramines are a disinfectant made from combining chlorine and ammonia.

⁴ Total organic carbon (TOC) has no health effects. However, TOC provides a means for the formation of disinfection by-products. One way to minimize disinfection by-product formation is to remove a specific percentage of the TOC present in the source water. The numbers in the Amount Detected and Range columns are the TOC removal factors, where the removal factor is defined as the actual percent TOC removal divided by the required percent removal. A value of 1.0 or greater in the Amount Detected column indicates that compliance with the removal requirement was achieved.

⁵ Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The treatment technique requires that at least 95% of routine samples are less than or equal to 0.3 NTU, and no sample exceeds 1 NTU. We are reporting the percentage of all readings meeting the standard of 0.3 NTU, plus the single highest reading for the year.

⁶ Compliance with the Lead and Copper Rule (LCR) is determined by the levels of lead and copper found in samples taken from customers' taps. LCR requirements are met if the 90th percentile of all samples taken does not exceed the action level of 15 ppb for lead or 1.300 ppm for copper.

⁷ Manganese is not currently regulated by USEPA. However, the state has set an MCL for manganese for supplies serving a population of 1000 or more. Manganese is not a health concern but can cause staining of plumbing and fixtures.

⁸ There is no state or federal MCL for sodium. Monitoring is required to provide information to consumers and health officials that are concerned about sodium intake due to dietary precautions. If you are on a sodium-restricted diet, you should consult a physician about this level of sodium in the water.

⁹ Zinc is not currently regulated by USEPA. However, the state has set an MCL for zinc and therefore monitoring is required.

¹⁰ A maximum contaminant level (MCL) for this substance has not been established by either state or federal regulations, nor has mandatory health effects language. The purpose for monitoring this substance is to assist USEPA in determining the occurrence of unregulated contaminants in drinking water, and whether future regulation is warranted.