



Kokomo – Phillips Street

Typical Water Quality Information

PWSID Number: 5234007

Area Served: Kokomo

Where Does My Water Come From?

North of North Street water comes primarily from groundwater wells treated at the Phillips Street Plant.

Average amount of water supplied to customers on a daily basis

1.6 million gallons per day

Parameter	Average or Range	Comments
pH	7.4	pH is a measure of the acid/base properties of water
Total Hardness (as CaCO ₃)	380 mg/L	Naturally occurring
Total Hardness (as CaCO ₃)	22 grains per gallon	Naturally occurring
Fluoride	0.8 mg/L	Naturally occurring and water additive, MCL = 4.0 mg/L
Sodium	12 mg/L	No MCL – Informational only
Iron	0.05 mg/L	Naturally occurring. Secondary Standard Limit = 0.3 mg/L
Manganese	0.01 mg/L	Naturally occurring. Secondary Standard Limit = 0.05 mg/L

Parameter	Average or Range	Comments
Type of disinfection	N/A	Chloramines
Disinfectant residual level leaving the treatment plant (average)	1.5 mg/L	Water additive to control microbes
Disinfectant residual level in the distribution system	1.7 mg/L	Max Residual Disinfectant Level Running Annual Avg. = 4.0 mg/L
Lead [90 th percentile result]	2 ug/L	Action Level = 15 ug/L
Copper [90 th percentile result]	0.414 mg/L	Action Level = 1.3 mg/L
Nitrate	ND	MCL = 10 mg/L
Arsenic	ND	MCL = 10 ug/L
Chromium-6	ND – 0.27 ug/L (ppb)	Chromium-6 is not currently regulated as an individual contaminant. For more information, please visit http://www.amwater.com/inaw/Ensuring-Water-Quality/Chromium-6

Definitions

- mg/L – milligrams per liter; one milligram per liter is equal to one part per million (ppm), which is approximately the same as 1 second in 11.5 days
- ug/L – micrograms per liter; one microgram per liter is equal to one part per billion (ppb), which is approximately the same as 1 second in 31.7 years
- N/A – not applicable
- ND – not detected
- MCL – Maximum Contaminant Level – the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the Water Quality Report located on the American Water web site.

For more information on your water quality, please contact
Kirk Kuroiwa at 764-457-5563

Other inquiries should be directed to our
Customer Service Center at 800-492-8373