



Antelope System

Typical Water Quality Information

PWSID Number: 3410031

Area Served: Unincorporated area north of Antelope Road, south of the Placer County line and northwest of the UPRR

Where Does My Water Come From? Water in the Antelope system comes from deep wells that pump groundwater from aquifers in the Sacramento Valley and from water purchased from Sacramento Suburban Water District (SSWD). The water supply is distributed for residential and commercial use.

Average amount of water supplied to customers on a daily basis
3.76 million gallons

The following data does not include purchased water from SSWD

Parameter	Average or Range	Comments
pH	Average = 7.6	A measurement of water acidity or alkalinity; 7.0 is neutral
Total Hardness (as CaCO ₃)	Average = 126 mg/L or 7.4 gpg	No MCL - Naturally occurring CaCO ₃ = Calcium Carbonate
Fluoride	Average = 0.2 mg/L	Naturally occurring; MCL = 2.0 mg/L
Sodium	Average = 31 mg/L	No MCL – Informational only
Iron	Range = < 100 – 310 µg/L	Secondary Standard Limit = 300 µg/L

Parameter	Average or Range	Comments
Manganese	Range = ND (< 20)	Secondary Standard Limit = 50 µg/L
Type of disinfection	N/A	Sodium Hypochlorite (chlorine)
Disinfectant residual level in the distribution system	Average = 0.7 mg/L	Max Residual Disinfectant Level Running Annual Avg. < or = 4.0 mg/L
Lead [90 th percentile result]	2 µg/L	Action Level = 15 µg/L
Copper [90 th percentile result]	0.279 mg/L	Action Level = 1.3 mg/L
Nitrate (as Nitrogen)	Range = 0.42 – 4.1 mg/L	MCL = 10 mg/L
Arsenic	Range = < 2.0 - 3.0 µg/L	MCL = 10 µg/L

Definitions

- Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment of other requirements which a water system must follow.
- gpg- grains per gallon; other units used to express water hardness (as Calcium Carbonate hardness) to convert gpg to mg/L; multiple gpg by 17.1.
- mg/L – milligrams per liter; one milligram per liter is equal to one part per million, which is approximately the same as 1 second in 11.5 days
- µg/L – micrograms per liter; one microgram per liter is equal to one part per billion, which is approximately the same as 1 second in 31.7 years
- N/A – not applicable
- ND – not detected
- MCL – Maximum Contaminant Level – the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the Water Quality Report located on the American Water web site

For more information about water quality in your area, please contact:

Victoria Kunda at 916-568-4278
or
Rachel Kennard at 916-568-4220

Other inquiries should be directed to our Customer Service Center at 1-888-237-1333