



Central States

Typical Water Quality Information

PWSID Number: IL1975210

Area Served: Plainfield

Where Does My Water Come From?

Well

Average amount of water supplied to customers on a daily basis

8,000 gallons per day

Parameter	Average or Range	Comments
pH	7.53	pH is a measure of the acid/base properties of water
Total Hardness (as CaCO ₃)	599 mg/L	Naturally occurring
Total Hardness (as CaCO ₃)	35 grains per gallon	Naturally occurring
Fluoride	0.87 mg/L	Naturally occurring and water additive, MCL = 4.0 mg/L
Sodium	17.1 mg/L	No MCL – Informational only
Iron	1340 ug/L	Natural content and water treatment chemicals
Manganese	23 ug/L	Naturally occurring from erosion of natural deposits
Chlorine	1.3-1.5 mg/L	Added for disinfection

Parameter	Average or Range	Comments
Lead [90 th percentile result]	6 ug/L	Corrosion of household plumbing; erosion of natural deposits
Copper [90 th percentile result]	0.296 mg/L	Corrosion of household plumbing; erosion of natural deposits
Nitrate	0 mg/L	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Arsenic	3 ug/L	MCL = 10 ug/L

Definitions

- mg/L – milligrams per liter; one milligram per liter is equal to one part per million, which is approximately the same as 1 second in 11.5 days
- ug/L – micrograms per liter; one microgram per liter is equal to one part per billion, which is approximately the same as 1 second in 31.7 years
- N/A – not applicable
- ND – not detected
- MCL – Maximum Contaminant Level – the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the Water Quality Report located on the American Water web site

For more information, please contact Laura Marcasciano at 630-739-8846 or laura.marcasciano@amwater.com.