



# Jaxson Estates

## Typical Water Quality Information

**PWSID Number:** MO6031461

### Where Does My Water Come From?

Ground Water Source

Parameter	Average or Range	Comments
pH	6.4 – 7.9	pH is the measure of the acid/base properties of water
Total Hardness (as CaCO <sub>3</sub> )	306 mg/L	Naturally occurring
Total Hardness (as CaCO <sub>3</sub> )	17.9 grains per gallon	Naturally occurring
Fluoride	1.4 mg/L	Naturally occurring MCL = 4.0 mg/L
Sodium	91.1 mg/L	No MCL – Informational only
Iron	0.3	Secondary Standard Limit = 0.3 mg/L
Manganese	ND	Secondary Standard limit = 0.05 mg/L
Type of disinfection	N/A	Chlorine
Disinfectant residual level leaving the treatment plant (average)	0.8 – 2.2 mg/L	Water additive to control microbes

<b>Parameter</b>	<b>Average or Range</b>	<b>Comments</b>
Disinfectant residual level in the distribution system	0.8 – 2.2 mg/L	Max Residual Disinfectant Level Running Annual Avg. = 4.0 mg/L
Lead [90 <sup>th</sup> percentile result]	5 ug/L	Action Level = 15 ug/L
Copper [90 <sup>th</sup> percentile result]	0.087 mg/L	Action Level = 1.3 mg/L
Nitrate	0.01	MCL = 10 mg/L
Arsenic	ND	MCL = 10 ug/L

**Definitions**

- mg/L – milligrams per liter; one milligram per liter is equal to one part per million (ppm), which is approximately the same as 1 second in 11.5 days
- ug/L – micrograms per liter; one microgram per liter is equal to one part per billion (ppb), which is approximately the same as 1 second in 31.7 years
- N/A – not applicable
- ND – not detected
- MCL – Maximum Contaminant Level – the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the [Water Quality Report](#) located on the American Water web site

For more information about water quality in your area, please contact our Water Quality Specialist at 314-436-6050 x6413

Other inquiries should be directed to our Customer Service Center at 866-430-0820