



Joplin

Typical Water Quality Information

PWSID Number: MO5010413

Area Served: Joplin, Webb City, Galena

Where Does My Water Come From?

Shoal Creek and/or Ground Water Sources

Average amount of water supplied to customers on a daily basis

12.9 million gallons per day

Parameter	Average or Range	Comments
pH	7.2 – 8.0	pH is a measure of the acid/base properties of water
Total Hardness (as CaCO ₃)	157 mg/L	Naturally occurring
Total Hardness (as CaCO ₃)	9.2 grains per gallon	Naturally occurring
Fluoride	0.6 mg/L	Naturally occurring and water additive, MCL = 4.0 mg/L
Sodium	6 mg/L	No MCL – Informational only
Iron	ND	Secondary Standard Limit = 0.3 mg/L
Manganese	0.003	Secondary Standard Limit = 0.05 mg/L

Parameter	Average or Range	Comments
Type of disinfection	N/A	Chlorine, Chloramines, Ultraviolet (UV)
Disinfectant residual level leaving the treatment plant (average)	3.0 mg/L	Water additive to control microbes
Disinfectant residual level in the distribution system	2.5 mg/L	Max Residual Disinfectant Level Running Annual Avg. = 4.0 mg/L
Lead [90 th percentile result]	3 ug/L	Action Level = 15 ug/L
Copper [90 th percentile result]	0.05 mg/L	Action Level = 1.3 mg/L
Nitrate	0.4 mg/L	MCL = 10 mg/L
Arsenic	ND ug/L	MCL = 10 ug/L
Chromium-6	0.17 – 0.25 ug/L	Chromium-6 is not currently regulated as an individual contaminant. For more information, please click here .

Definitions

- mg/L – milligrams per liter; one milligram per liter is equal to one part per million (ppm), which is approximately the same as 1 second in 11.5 days
- ug/L – micrograms per liter; one microgram per liter is equal to one part per billion (ppb), which is approximately the same as 1 second in 31.7 years
- N/A – not applicable
- ND – not detected
- MCL – Maximum Contaminant Level – the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the [Water Quality Report](#) located on the American Water web site

For more information about water quality in your area, please contact our Water Quality Supervisor at 417-626-8509 ext. 2008

Other inquiries should be directed to our Customer Service Center at 866-430-0820