



Lincoln

Typical Water Quality Information

PWSID Number: IL1075030

Area Served: Lincoln

Where Does My Water Come From?

The source of water for the Lincoln District is groundwater. Several wells draw water from the Mahomet Teays Valley Aquifer. An aquifer is a porous underground formation (such as sand or gravel) that is saturated with water.

Average amount of water supplied to customers on a daily basis

2.4 million gallons per day

Parameter	Average or Range	Comments
pH	7.2-7.6	pH is a measure of the acid/base properties of water
Total Hardness (as CaCO ₃)	330 mg/L	Naturally occurring calcium/magnesium content in water
Total Hardness (as CaCO ₃)	19.8 grains per gallon	Naturally occurring calcium/magnesium content in water
Fluoride	0.9-1.19 mg/L	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Sodium	13.7-14.3 mg/L	Erosion of naturally occurring deposits; used in water softener regeneration. There is no state or federal MCL for sodium
Manganese	ND-0.043 mg/L	Erosion of naturally occurring deposits Secondary Standard Limit = 0.05 mg/L

Parameter	Average or Range	Comments
Type of disinfection	N/A	Free Chlorine
Disinfectant residual level leaving the treatment plant (average)	0.54-0.69 mg/L	Water additive to control microbes
Disinfectant residual level in the distribution system	0.70 mg/L	Max Residual Disinfectant Level Running Annual Avg. = 4.0 mg/L
Lead [90 th percentile result]	1 ug/L	Action Level = 15 ug/L
Copper [90 th percentile result]	1.05 mg/L	Action Level = 1.3 mg/L
Nitrate	ND-0.50 mg/L	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits MCL = 10 mg/L
Hexavalent Chromium	ND-0.03 mg/L	An MCL for this substance has not been established by either state or federal regulations, nor has mandatory health effects language. The purpose for monitoring this substance is to assist USEPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. There are currently no regulations for Hexavalent Chromium (Chromium 6).

Definitions

- mg/L – milligrams per liter; one milligram per liter is equal to one part per million, which is approximately the same as 1 second in 11.5 days
- ug/L – micrograms per liter; one microgram per liter is equal to one part per billion, which is approximately the same as 1 second in 31.7 years
- N/A – not applicable
- ND – not detected
- MCL – Maximum Contaminant Level – the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the Water Quality Report located on the American Water web site

For more information about water quality in your area, please contact
Pamela Ingersoll at 1-309-566-4161

Other inquiries should be directed to our
Customer Service Center at 800-422-2782