



System Name

Typical Water Quality Information

PWSID Number: 5229015

Area Served: Noblesville 46060, 46061, Fishers 46038

Where Does My Water Come From?

Groundwater wells located in 2 well fields

Average amount of water supplied to customers on a daily basis

4.2 million gallons per day

Parameter	Average or Range	Comments
pH	7.8	
Total Hardness (as CaCO ₃)	350 - 400 mg/L	Naturally occurring
Total Hardness (as CaCO ₃)	20 - 23 grains per gallon	Naturally occurring
Fluoride	0.75 mg/L	Naturally occurring and water additive, MCL = 4.0 mg/L
Sodium	21.5 mg/L	No MCL – Informational only
Iron	.03 mg/L	Secondary Standard Limit = 0.3 mg/L
Manganese	.01 mg/L	Secondary Standard Limit = 0.05 mg/L

Parameter	Average or Range	Comments
Type of disinfection	N/A	Free Chlorine
Disinfectant residual level leaving the treatment plant (average)	0.9 mg/L	Water additive to control microbes
Disinfectant residual level in the distribution system	0.8 mg/L	Max Residual Disinfectant Level Running Annual Avg. = 4.0 mg/L
Lead [90 th percentile result]	3 ug/L	Action Level = 15 ug/L
Copper [90 th percentile result]	.143 mg/L	Action Level = 1.3 mg/L
Nitrate	ND – 0.4	MCL = 10 mg/L
Arsenic	ND	MCL = 10 ug/L

Definitions

- mg/L – milligrams per liter; one milligram per liter is equal to one part per million, which is approximately the same as 1 second in 11.5 days
- ug/L – micrograms per liter; one microgram per liter is equal to one part per billion, which is approximately the same as 1 second in 31.7 years
- N/A – not applicable
- ND – not detected
- MCL – Maximum Contaminant Level – the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the Water Quality Report located on the American Water web site

For more information, please contact our Customer Service Center at 1-800-492-8373