

Richmond

Typical Water Quality Information

PWSID Number: IN5289012

Area Served: Richmond, Indiana

Where Does My Water Come From?

Surface Water from reservoir and collector wells; Ground Water from wells

and springs

Average amount of water supplied to customers on a daily basis

5.6 million gallons per day

Parameter	Average or Range	Comments
рН	7.4	
Total Hardness (as CaCO3)	323 mg/L	Naturally occurring
Total Hardness (as CaCO3)	19 grains per gallon	Naturally occurring
Fluoride	0.7 mg/L	Naturally occurring and water additive, MCL = 4.0 mg/L
Sodium	31.8 mg/L	No MCL – Informational only
Iron	0.01	Secondary Standard Limit = 0.3 mg/L
Manganese	0.02	Secondary Standard Limit = 0.05 mg/L

Typical Water Quality 1

Parameter	Average or Range	Comments
Type of disinfection	N/A	Chloramines
Disinfectant residual level leaving the treatment plant (average)	2.5 mg/L	Water additive to control microbes
Disinfectant residual level in the distribution system	2.0 mg/L	Max Residual Disinfectant Level Running Annual Avg. = 4.0 mg/L
Lead [90 th percentile result]	14 ug/L	Action Level = 15 ug/L
Copper [90 th percentile result]	0.582 mg/L	Action Level = 1.3 mg/L
Nitrate	2.24 mg/L	MCL = 10 mg/L
Arsenic	ND ug/L	MCL = 10 ug/L

Definitions

- mg/L milligrams per liter; one milligram per liter is equal to one part per million (ppm), which
 is approximately the same as 1 second in 11.5 days
- ug/L micrograms per liter; one microgram per liter is equal to one part per billion (ppb),
 which is approximately the same as 1 second in 31.7 years
- N/A not applicable
- ND not detected
- MCL Maximum Contaminant Level the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the Water Quality Report located on the American Water web site

For more information, please contact our Customer Service Center at 1-800-492-8373

Typical Water Quality 2