



Short Hills System

Typical Water Quality Information

PWSID Number: NJ0712001

Area Served: Chatham Borough, Chatham Township, East Hanover, Florham Park, Harding (Green Village), Madison, Roseland, Verona, West Orange

Where Does My Water Come From?

Purchased surface water supplies from the Passaic Valley Water Commission and North Jersey District Water Supply Commission

Average amount of water supplied to customers on a daily basis

42 million gallons per day total system-wide usage

Parameter	Average or Range	Comments
pH	7.7 – 8.2	
Total Hardness (as CaCO ₃)	88 - 186 mg/L	Naturally occurring
Total Hardness (as CaCO ₃)	5 – 11 grains per gallon	Naturally occurring
Fluoride	ND – 0.11 (Naturally occurring)	Naturally occurring and water additive, MCL = 4.0 mg/L
Sodium	45 - 129 mg/L	No MCL – Informational only
Iron	ND – 0.017	Secondary Standard Limit = 0.3 mg/L

Parameter	Average or Range	Comments
Manganese	ND – 0.005	Secondary Standard Limit = 0.05 mg/L
Type of disinfection	N/A	Chlorine
Disinfectant residual level leaving the treatment plant (average)	1.2 mg/L	Water additive to control microbes
Disinfectant residual level in the distribution system	0.59 – 1.0 mg/L	Max Residual Disinfectant Level Running Annual Avg. = 4.0 mg/L
Lead [90 th percentile result]	2 - 3 ug/L	Action Level = 15 ug/L
Copper [90 th percentile result]	0.323 – 0.348 mg/L	Action Level = 1.3 mg/L
Nitrate	0.52 – 4.33 mg/L	MCL = 10 mg/L
Arsenic	ND	MCL = 5 ug/L

Definitions

- mg/L – milligrams per liter; one milligram per liter is equal to one part per million (ppm), which is approximately the same as 1 second in 11.5 days
- ug/L – micrograms per liter; one microgram per liter is equal to one part per billion (ppb), which is approximately the same as 1 second in 31.7 years
- N/A – not applicable
- ND – not detected
- MCL – Maximum Contaminant Level – the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the Water Quality Report located on the American Water web site

For more information, please contact our Water Quality Inquiry Hot-Line at 973-564-5754 between the hours 8 AM and 3 PM, Monday through Friday

For all other inquiries, please contact our Customer Service Center at 1-800-272-1325