



West Placer System

Typical Water Quality Information

PWSID Number: 3110150

Area Served: West Placer area

Where Does My Water Come From? Water in the West Placer system comes from purchased water from Placer County Water Agency through the City of Roseville. The water supply is distributed for residential and commercial use.

Average amount of water supplied to customers daily
767,049 gallons

Parameter	Average or Range	Comments
pH	Average = 8.5	A measurement of water acidity or alkalinity; 7.0 is neutral
Total Hardness (as CaCO ₃)	Average = 271 mg/L or 1.5 gpg	No MCL - Naturally occurring CaCO ₃ = Calcium Carbonate
Fluoride	Average = 0.77 mg/L	Water additive that promotes strong teeth; Control Range = 0.6 mg/L to 1.2 mg/L
Sodium	Average = 4.2 mg/L	No MCL – Informational only
Iron	Average = ND (< 100 µg/L)	Secondary Standard Limit = 300 µg/L
Manganese	Average = ND (< 20 µg/L)	Secondary Standard Limit = 50 µg/L

Parameter	Average or Range	Comments
Type of disinfection	N/A	Sodium Hypochlorite (chlorine)
Disinfectant residual level in the distribution system	Average = 0.72 mg/L	Max Residual Disinfectant Level Running Annual Avg. < or = 4.0 mg/L
Lead [90 th percentile result]	ND	Action Level = 15 µg/L
Copper [90 th percentile result]	ND	Action Level = 1.3 mg/L
Nitrate (as Nitrogen)	Average = ND (< 0.4 mg/L)	MCL = 10 mg/L
Arsenic	Average = ND (< 2 µg/L)	MCL = 10 µg/L

Definitions

- Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment of other requirements which a water system must follow.
- gpg- grains per gallon; other units used to express water hardness (as Calcium Carbonate hardness) to convert gpg to mg/L; multiple gpg by 17.1.
- mg/L – milligrams per liter; one milligram per liter is equal to one part per million, which is approximately the same as 1 second in 11.5 days
- µg/L – micrograms per liter; one microgram per liter is equal to one part per billion, which is approximately the same as 1 second in 31.7 years
- N/A – not applicable
- ND – not detected
- MCL – Maximum Contaminant Level – the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the Water Quality Report located on the American Water web site

For more information about water quality in your area, please contact:

Victoria Kunda at 916-568-4278
or
Rachel Kennard at 916-568-4220

Other inquiries should be directed to our Customer Service Center at 1-888-237-1333