



# Winchester

## Typical Water Quality Information

**PWSID Number:** IN5268003

**Area Served:** Winchester, Indiana

**Where Does My Water Come From?**

Ground water from wells

**Average amount of water supplied to customers on a daily basis**

0.53 million gallons per day

Parameter	Average or Range	Comments
pH	7.5	
Total Hardness (as CaCO <sub>3</sub> )	414 mg/L	Naturally occurring
Total Hardness (as CaCO <sub>3</sub> )	24 grains per gallon	Naturally occurring
Fluoride	0.73 mg/L	Naturally occurring and water additive, MCL = 4.0 mg/L
Sodium	23.9 mg/L	No MCL – Informational only
Iron	0.02	Secondary Standard Limit = 0.3 mg/L
Manganese	0.01	Secondary Standard Limit = 0.05 mg/L

<b>Parameter</b>	<b>Average or Range</b>	<b>Comments</b>
Type of disinfection	N/A	Free Chlorine
Disinfectant residual level leaving the treatment plant (average)	1.1 mg/L	Water additive to control microbes
Disinfectant residual level in the distribution system	0.8 mg/L	Max Residual Disinfectant Level Running Annual Avg. = 4.0 mg/L
Lead [90 <sup>th</sup> percentile result]	13 ug/L	Action Level = 15 ug/L
Copper [90 <sup>th</sup> percentile result]	0.153 mg/L	Action Level = 1.3 mg/L
Nitrate	0.02	MCL = 10 mg/L
Arsenic	ND	MCL = 10 ug/L

**Definitions**

- mg/L – milligrams per liter; one milligram per liter is equal to one part per million (ppm), which is approximately the same as 1 second in 11.5 days
- ug/L – micrograms per liter; one microgram per liter is equal to one part per billion (ppb), which is approximately the same as 1 second in 31.7 years
- N/A – not applicable
- ND – not detected
- MCL – Maximum Contaminant Level – the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the Water Quality Report located on the American Water web site.

For more information, please contact our Customer Service Center at 1-800-492-8373