



2019 WATER QUALITY REPORT

Prince William District
PWSID: VA6153625



Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

This report contains important information about your drinking water. If you do not understand it, please have someone translate it for you.

A Message from the Virginia American Water President



To Our Valued Customers:

Virginia American Water is proud to be your local water service provider, and I am pleased to share with you good news about the quality of your drinking water. Each year, we provide you with our Annual Water Quality Report, and Virginia American Water continues to supply drinking water that meets or surpasses all state and federal water quality regulations.

Virginia American Water delivers high quality water to your homes and businesses by maintaining and improving the miles of pipeline hidden below the ground, the facilities that draw water from the source and the plants where the water is treated and tested.

Our plant operators, water quality experts, engineers and maintenance crews work diligently to protect our water supplies and provide our communities with safe, clean tap water. Delivering reliable water service to your tap also requires significant investment to upgrade the aging water infrastructure. In 2019 alone, we invested more than \$35 million in water system improvements statewide.

We do this because Virginia American Water delivers more than just water service. We distribute a key resource for public health, fire protection, the economy and overall quality of life. Our job is to provide quality water not only today, but well into the future. It's part of our commitment to you and the communities we serve. We hope you agree that your water quality is worth every penny, and worth learning more about.

Please spend time reviewing this report. You'll learn details about the source and quality of your drinking water using data from water quality testing conducted for your local water system from January through December 2019.

Thanks for allowing us to serve you.

Sincerely,

Barry Suits, P.E.



QUALITY. ONE MORE WAY WE KEEP LIFE FLOWING.

Information on the Internet

Virginia American Water, a subsidiary of American Water Works Company, Inc. (NYSE: AWK), is the largest investor-owned water utility in the state, providing high quality and reliable water services to approximately 320,000 people.

With a history dating back to 1886, American Water is the largest and most geographically diverse U.S. publicly traded water and wastewater utility company. The company employs more than 6,800 dedicated professionals who provide regulated and market-based drinking water, wastewater and other related services to an estimated 15 million people in 46 states. American Water provides safe, clean, affordable and reliable water services to our customers to help keep their lives flowing. For more information, visit www.amwater.com and follow American Water on [Twitter](#), [Facebook](#), and [LinkedIn](#).

The U.S. Environmental Protection Agency (EPA Office of Water (www.epa.gov/safewater) and the Centers for Disease Control and Prevention (CDC) (www.cdc.gov) websites provide a substantial amount of information on many issues relating to water resources, water conservation and public health. Also, the Virginia Department of Health (VDH) and the Virginia Department of Environmental Quality (DEQ) have websites that provide complete and current information on water issues in Virginia. These websites are located at (www.vdh.virginia.gov) and (www.deq.state.va.us). All these websites have numerous links that will direct you to other professional organizations, public education and public health topics related to water.

Share This Report

Landlords, businesses, schools, hospitals and other groups are encouraged to share this important water quality information with water users at their location who are not billed customers of Virginia American Water and therefore do not receive this report directly.

What Is a Water Quality Report?

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

To comply with VDH and EPA regulations, Virginia American Water issues a report annually describing the quality of your drinking water. The purpose of this report is to provide you an overview of last year's (2019) drinking water quality. It includes details about where your water comes from and the results of our testing. We hope the report will raise your understanding of drinking water issues and awareness of the need to protect your drinking water sources.

Where Does My Water Come From?

Virginia American Water, Prince William District is classified as a consecutive water system. Your drinking water comes from a surface water treatment plant owned and operated by Fairfax Water. The Griffith plant is at the Occoquan Reservoir. To learn more about our watershed on the Internet, go to USEPA's Search Your Watershed at <https://watersgeo.epa.gov/mywaterway>.



QUALITY. ONE MORE WAY WE KEEP LIFE FLOWING.

Protecting your Drinking Water Supply

Protecting drinking water at its source is an important part of the process to treat and deliver high quality water. It takes a community effort to protect our shared water resources. This includes utilities, businesses, residents, government agencies and organizations. Everyone who lives, works, and plays in the area has a role and stake in clean water supplies.

What Can you do? Quality drinking water starts upstream. Everyone can help maintain and improve drinking water supplies through the following actions:

- Dispose of pharmaceuticals, household chemicals, oils and paints at proper waste collections sites. Materials can impact water ways if poured down the drain, flushed down the toilet, or dumped on the ground. Contact your county waste authority to find out how to dispose of these materials properly
- Check for leaks from automobiles and heating fuel tanks. Clean up any spills using an absorbent material like cat litter. Sweep up the material and put it in a sealed bag in the trash.
- Clean up after your pets and limit the use of fertilizers and pesticides.
- Look for local opportunities to take part in watershed activities.
- Report any spills, illegal dumping or suspicious activity to VDEQ Pollution Response Program (PREP) (804) 527-5020.

What Are We Doing? Our vision is Clean Water for Life. Our priority is to provide reliable, quality drinking water for our customers. The source of supply is an important part of that mission. We work to understand and reduce potential risks to your drinking water supply.

Here are a few of the efforts underway to protect our shared water resources:

- Community Involvement: We have a proactive public outreach program to help spread the word and get people involved. This includes school education, and other community activities. For more information, visit: <https://amwater.com/vaaw/news-community/community-involvement>.
- Environmental Grant Program: Each year, we fund projects that improve water resources in our local communities. For more information on the program, visit : <https://amwater.com/vaaw/about-us/environmental-grant-program>.

To learn more about your water supply and local activities, please contact Kelly Ryan at (804) 446-9822

Why does my water sometimes have a chlorine taste and odor?

During the months of April, May, and June, you may notice the taste and odor of chlorine in your water. Every year, during this time, Fairfax Water uses free chlorine instead of the less noticeable combined chlorine (chloramines) as a disinfectant during distribution system flushing. Free chlorine is used during the water main flushing program done each year to maintain a high level of water quality.



Cryptosporidium Information for Potomac River and Occoquan Reservoir

Cryptosporidium is a microbial pathogen sometimes found in surface water throughout the United States. Although filtration removes *Cryptosporidium*, the most commonly used filtration methods cannot guarantee 100 percent removal. Fairfax Water consistently maintains its filtration process in accordance with regulatory guidelines to maximize removal efficiency. Our monitoring indicates the occasional presence of these organisms in the source water. Current test methods do not allow us to determine whether the organisms are dead or if they are capable of causing disease.

Ingestion of *Cryptosporidium* may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immunocompromised people, infants and small children, and the elderly are at greater risk of developing life-threatening illness. We encourage immunocompromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection.

Monitoring for compliance with the LT2ESWTR Round 2 was completed in March 2017.

Under the LT2ESWTR Round 2, the average *Cryptosporidium* concentration determines whether additional treatment measures are needed. A *Cryptosporidium* concentration of 0.075 oocysts/Liter triggers additional water treatment measures. Fairfax Water's raw water *Cryptosporidium* concentrations were below this threshold. The results for LT2ESWTR Round 2 monitoring period of 2015 – 2017 are as follows:

Source (before treatment)	Average <i>Cryptosporidium</i> concentration (oocysts/Liter)	Final Bin assessment under LT2ESWTR Round 2
Potomac River	ND	Bin 1 (no additional treatment required)
Occoquan Reservoir	0.01	Bin 1 (no additional treatment required)

Special Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the USEPA's Safe Drinking Water Hotline (800) 426-4791.

Water Information Sources

- Virginia American Water
www.amwater.com/vaaw
- Virginia Department of Health
www.amwater.com/vaaw
- United States Environmental Protection Agency (USEPA)
www.epa.gov/safewater
- Safe Drinking Water Hotline: (800) 426-4791
- Centers for Disease Control and Prevention
www.cdc.gov
- American Water Works Association
www.awwa.org
- National Library of Medicine/National Institute of Health
www.nlm.nih.gov/medlineplus



QUALITY. ONE MORE WAY WE KEEP LIFE FLOWING.

Other Water Quality Parameters of Interest in Water, Not Regulated

What is the pH range of your water?

Water produced by Fairfax Water's treatment facilities averaged 7.4 pH units in the Prince William Distribution system. A pH of 7.0 is considered neutral, neither acidic or nor basic.

How hard is your water?

Total hardness is a measure of the concentration of two minerals naturally present in water: calcium and magnesium. High hardness levels cause soap not to foam as easily as it would at lower levels. Hardness levels averaged 74 parts per million or 4.32 grains per gallon which is considered to be moderately hard.

How much sodium is in your water?

The sodium level was 32.8 ppm. This concentration exceeds the recommended maximum contaminant level of 20 mg/L for persons on a "strict" sodium diet.

Substances Expected to be in Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. Environmental Protection Agency's Safe Drinking Water Hotline (800) 426-4791.

The source of drinking water (both tap water and bottled water) includes rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife.

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and may also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Virginia American Water is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using the water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800) 426-4791 or at <http://www.epa.gov/safewater/lead>.

Virginia American Water remains in compliance with all of the requirements dealing with lead in drinking water. If you are concerned about lead in your water, then you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800) 426-4791 or at <http://www.epa.gov/safewater/lead>.

We take steps to reduce the potential for lead to leach from your pipes into the water. There are also steps that you can take to reduce your household's exposure to lead in drinking water. For more information, please review our Lead and Drinking Water Fact Sheet at <https://amwater.com/vaaw/water-quality/lead-and-drinking-water>.



QUALITY. ONE MORE WAY WE KEEP LIFE FLOWING.

How to Read the Data Tables

Virginia American Water conducts extensive monitoring. The results of our monitoring are reported in the accompanying tables. While most monitoring was conducted in 2019, certain substances are only monitored once every three to nine years because the levels do not change frequently. For help with interpreting this table, see the “Table Definitions” section.

Starting with a **Substance**, read across. **Year Sampled** is usually in 2019 or year prior. **MCL** shows the highest level of substance (contaminant) allowed. **MCLG** is the goal level for that substance (this may be lower than what is allowed). **Average Amount Detected** represents the measured amount (less is better). **Range** tells the highest and lowest amounts measured. A **Yes** under **Compliance Achieved** means the amount of the substance met government requirements. **Typical Source** tells where the substance usually originates.

Unregulated substances are measured, but maximum allowed contaminant levels have not been established by the government.

Table Definitions and Abbreviations

- **Action Level:** The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.
- **MCL (Maximum Contaminant Level):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **MCLG (Maximum Contaminant Level Goal):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MRDL (Maximum Residual Disinfectant Level):** The highest level of disinfectant routinely allowed in drinking water. Addition of a disinfectant is necessary for control of microbial contaminants.
- **MRDLG (Maximum Residual Disinfectant Level Goal):** The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- **NA:** Not applicable
- **ND:** Not detected
- **NRL:** No regulatory limit
- **NTU - Nephelometric Turbidity Units:** Measurement of the clarity, or turbidity, of water.
- **pCi/L (picocuries per liter):** Measurement of the natural rate of disintegration of radioactive contaminants in water (also beta particles).
- **ppm (parts per million):** One part substance per million parts water, or milligrams per liter.
- **ppb (parts per billion):** One part substance per billion parts water, or micrograms per liter.
- **TT (Treatment Technique):** A required process intended to reduce the level of a contaminant in drinking water.
- **SS:** Single sample
- **%:** - means percent.
- **>:** - means greater than.
- **<:** - means less than.



QUALITY. ONE MORE WAY WE KEEP LIFE FLOWING.

Water Quality Statement

For your information, we have compiled a list in the table below showing the results of the testing of your drinking water during 2019.

Your Drinking Water Quality Meets State and Federal Requirements

Turbidity – A Measure of the Clarity of the Process Water from Fairfax Water Treatment Facility (Griffith Plant)

Year Sampled	MCL ³	MCLG	Average Annual Turbidity	Highest Single Measurement	Lowest Monthly % Samples Meeting Treatment Technique Turbidity Limit	Compliance Achieved	Major Source in Drinking Water
2019	TT ¹ (NTU) ²	TT (NTU)	0.03	0.16	100%	Yes	Soil runoff

¹ TT = Treatment Technique

² NTU = Nephelometric Turbidity Unit

³ Turbidity levels are measured during the treatment process after the water has been filtered, but before disinfection. The turbidity level of filtered water shall be less than or equal to 0.3 NTU in at least 95% of the measurements taken each month and shall at no time exceed 1 NTU.

Total Organic Carbon (TOC) Removal Measured from Fairfax Water Treatment Facility (Griffith Plant)

Total Organic Carbon has no health effects. However, it provides a medium for the formation of disinfection by-products. These by-products include trihalomethanes and haloacetic acids. Compliance with the treatment technique (TT) reduces the formation of these disinfection by-products

Year Sampled	MCL	MCLG	Quarterly Running Annual Average ⁴	Minimum	Maximum	Compliance Achieved	Major Source in Drinking Water
2019	TT ¹ (ratio)	NA	1.6	1.5	1.6	Yes	Naturally present in the environment

¹ TT = Treatment technique.

⁴ Quarterly Running Annual Average (QRAA) of the monthly ratio of actual Total Organic Carbon (TOC) removal versus required TOC removal. QRAA is to be ≥ 1 to be in compliance.

NA = not applicable.

Bacterial Results (Measured in the Prince William Distribution Network)

Substance (units)	Year Sampled	MCLG	MCL ⁵	Highest Percentage Detected	Compliance Achieved	Typical Source
Total Coliform (% Positive samples)	2019	0	5 %	0%	Yes	Bacteria naturally present in the environment

⁵ No more than 5% of all samples tested monthly can be positive.

Disinfection Levels (Measured in the Prince William Distribution Network)

Substance (units)	Year Sampled	MRDL	MCL	Highest monthly average	Range Low-High	Compliance Achieved	Typical Source
Total Chlorine (ppm) ⁶	2019	4	NA	2.5	0.8 - 3.2	Yes	Disinfectant used to control microbes

⁶ Total Chlorine (Distribution System): In addition to chloramines, free chlorine was used as a disinfectant during the spring. The data shows values for both chlorine and chloramine levels.

Regulated Substances (Measured in the Prince William Distribution System) - Disinfection By-products

Substance (units)	Year Sampled	MCL	Average Amount Detected ⁷	Range Low-High ⁸	Compliance Achieved	Typical Source
Total Trihalomethanes [TTHM] (ppb) ⁷	2019	80	36.9	5.0 - 68.4	Yes	By-product of drinking water chlorination
Total Haloacetic Acids [THAA5] (ppb) ⁷	2019	60	31.7	ND - 54.5	Yes	By-product of drinking water chlorination

⁷ Average amount detected is the highest locational running annual average of the 8 stage two disinfection byproduct compliance sample sites

⁸ Range is determined using results from all compliance sites



QUALITY. ONE MORE WAY WE KEEP LIFE FLOWING.

Tap Water Samples Measured in the Prince William Distribution System: Lead and Copper Results June – August 2019

Substance (units)	Period of Year Sampled	MCLG	Action Level	Amount Detected 90th Percentile	Number of Samples	Homes Above Action Level	Compliance Achieved	Typical Source
Copper (ppm)	June- August	1.3	1.3	0.120	31	0	Yes	Corrosion of household plumbing
Lead (ppb)	June- August	0	15	ND	31	0	Yes	Corrosion of household plumbing

Regulated Substances (Measured in the Water Entering the Distribution Network by Fairfax Water Griffith Facility)

Substance (units)	Year Sampled	MCLG	MCL	Average Amount Detected	Range Low-High	Compliance Achieved	Typical Source
Barium (ppm)	2019	2	2	0.018	ND – 0.038	Yes	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Beta / photon emitters ⁹ (pCi/L) ¹⁰	2019	0	50	2.63	NA	Yes	Decay of natural and man-made deposits
Fluoride (ppm)	2019	4	4	0.7	0.6 – 0.8	Yes	Erosion of natural deposits; Water additive which promotes strong teeth
Nitrate - as nitrogen (ppm)	2019	10	10	0.90	0.62 – 1.30	Yes	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

⁹ pCi/L= picocuries per liter. This radioactive contaminant result is above the analysis-specific detection limit but below the minimum detection limits (DL) prescribed in the Consumer Confidence Rule as stated in 40 CFR 1141.151 (d). This result may not be required to be reported in the CCR.

¹⁰ The MCL for the Beta particles is written as 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for Beta particles.

Unregulated Substances (Measured in the Prince William Distribution System)

Substance (units)	Year Sampled	MCLG	MCL	Amount Detected	Range Low-High	Compliance Achieved	Typical Source
Chloroform (ppb)	2019	NRL ¹¹	NRL ¹¹	56.4	2.1 – 56.4	NA	By-product of drinking water disinfection
Bromodichloromethane (ppb)	2019	NRL ¹¹	NRL ¹¹	9.5	1.8 – 9.5	NA	By-product of drinking water disinfection
Chlorodibromomethane (ppb)	2019	NRL ¹¹	NRL ¹¹	3.8	1.0 – 3.8	NA	By-product of drinking water disinfection
Bromochloroacetic acid (ppb)	2019	NRL ¹¹	NRL ¹¹	5.1	ND – 5.1	NA	By-product of drinking water disinfection
Dichloroacetic acid (ppb)	2019	NRL ¹¹	NRL ¹¹	28.1	ND – 28.1	NA	By-product of drinking water disinfection
Trichloroacetic acid (ppb)	2019	NRL ¹¹	NRL ¹¹	19.7	ND – 19.7	NA	By-product of drinking water disinfection
Dibromoacetic acid (ppb)	2019	NRL ¹¹	NRL ¹¹	1.3	ND – 1.3	NA	By-product of drinking water disinfection
Chlorate (ppm)	2019	NRL ¹¹	NRL ¹¹	0.30	0.14 – 0.30	NA	By-product of drinking water disinfection
Bromide (ppm)	2019	NRL ¹¹	NRL ¹¹	0.04	ND – 0.04	NA	By-product of drinking water disinfection
Monochloroacetic acid (ppb)	2019	NRL ¹¹	NRL ¹¹	5.7	ND – 5.7	NA	By-product of drinking water disinfection

¹¹ NRL = No regulatory limit.

Unregulated Substances (From the Distribution System) UCMR 3¹²

Substance (units)	Year Sampled	Results	Range Low-High	Typical Source
Chlorate (ppb)	2015	150	140 – 150	Naturally occurring, discharge from steel and electronics manufacturing
Chromium (ppb)	2015	11.4	ND – 11.4	Discharge from steel and pulp mills
Hexavalent Chromium (ppb)	2015	0.12	0.10 – 0.12	Discharge from steel and pulp mills
Strontium (ppb)	2015	123.2	82.9– 123.2	Soil Runoff
Vanadium (ppb)	2015	0.4	ND – 0.4	Discharge from power plants; erosion of natural deposits

¹² Unregulated Substances (from the distribution system) are results from disinfection by-product sampling sites required by UCMR 3 rule.



QUALITY. ONE MORE WAY WE KEEP LIFE FLOWING.