



NOTES:

1. CENTER METER IN BOX, MIN 5" CLEARANCE ON ALL SIDES.
2. TRENCH, INSTALL, AND BACKFILL SERVICE LINE IN ACCORDANCE WITH AW SPECIFICATIONS.
3. POINT OF DEMARCATION FOR SERVICE LINE OWNERSHIP PER PRIME CONTRACT BETWEEN AW AND GOVERNMENT.
4. SERVICE LINE MATERIALS SHALL MEET AW SPECIFICATIONS.
5. SERVICE LINE BEDDING SHALL BE IN ACCORDANCE WITH AW SPECIFICATIONS.
6. IF WATER SERVICE BETWEEN MAIN AND WATER METER IS REPLACED WITH NON-METALLIC PIPING, THERE SHALL BE A MINIMUM LENGTH OF TEN (10) FT OF METALLIC PIPING BETWEEN THE BUILDING STRUCTURE AND METER PIT TO MAINTAIN PROPER GROUNDING OF BUILDING'S ELECTRICAL SYSTEM.

WATER SERVICE INSTALLATION (2" AND SMALLER SERVICE)

REVISIONS	AMERICAN WATER MILITARY SERVICES GROUP CIVIL 2" WATER SERVICE INSTALLATION DETAIL
5/10 - MSG EDITS	AMERICAN WATER MILITARY SERVICES GROUP CAMDEN, NJ 08102
1/12 - MSG EDITS	
6/13 - MSG EDITS	
7/14 - MSG EDITS	
1/16 - MSG EDITS	
	AMERICAN WATER M.S.G. CAMDEN, NJ 08102 MT LAUREL, NJ 08054
	AMERICAN WATER.
	DRAWN BY Z. ALAM PROJECT ENGR'R PDK APPROVED
	DATE 05-03-2010 PROJECT N/A
	USE DIMENSIONS ONLY SCALE N.T.S.
	USE APPROVED DRAWINGS ONLY FOR CONSTRUCTION PURPOSES
	MSG-W-01-FH

FINAL

MSG-W-01-FH