



## CONNECTION TO EXISTING MANHOLE

**NOTES:**

1. CORE DRILL NEW PIPE OPENING.
2. INSERT NEW FLEXIBLE CONNECTOR.
3. AFTER INSERTION OF NEW PIPE, MANHOLE SHALL BE VACUUM TESTED IN ACCORDANCE WITH SPECIFICATIONS.

\* BRICK MANHOLES CAN NOT BE CORE DRILLED

REVISIONS
6/13 - MSG EDITS
01/16 - MSG EDITS

AMERICAN WATER MILITARY SERVICES GROUP  
CIVIL  
CONNECTION TO EXISTING MANHOLE  
DETAIL

AMERICAN WATER MILITARY SERVICES GROUP  
CAMDEN, NJ 08102

AMERICAN WATER M.S.G.  
1 WATER STREET  
CAMDEN, NJ 08102



DRAWN BY J. ABRERA  
PROJECT ENG'R PDK  
APPROVED

DATE 04-30-2010  
PROJECT N/A

USE DIMENSIONS ONLY  
SCALE N.T.S.

USE APPROVED DRAWINGS ONLY  
FOR CONSTRUCTION PURPOSES

MSG-WW-12

FINAL

MSG-WW-12