



## TYPICAL MANHOLE VENT

### NOTES:

1. VENT OPENING SHALL BE MIN. 4'-0" ABOVE FINISHED GRADE OR MIN. 1' ABOVE 100 YEAR FLOODPLAIN ELEVATION.
2. PRIME AND PAINT EXPOSED DIP USING TWO COATS OF POLYURETHANE. COLOR TO BE SELECTED BY PROJECT MANAGER FROM MANUFACTURER'S STANDARD COLORS.

REVISIONS
1/16 - MSG EDITS

AMERICAN WATER MILITARY SERVICES GROUP  
CIVIL  
MANHOLE VENT  
DETAIL

AMERICAN WATER MILITARY SERVICES GROUP  
CAMDEN, NJ 08102

AMERICAN WATER M.S.G.  
1 WATER STREET  
CAMDEN, NJ 08102



DRAWN BY  
PROJECT ENG'R PDK  
APPROVED

DATE 6-24-2013  
PROJECT N/A

USE DIMENSIONS ONLY  
SCALE N.T.S.

USE APPROVED DRAWINGS ONLY  
FOR CONSTRUCTION PURPOSES

MSG-WW-15

FINAL

MSG-WW-15