



SANITARY FORCE MAIN CLEANOUT DETAIL

NOTES:

1. VALVES, VALVE BOXES AND VALVE EXTENSIONS SHALL MEET THE SAME REQUIREMENTS AS SHOWN IN THE STANDARD WATER DETAILS.
2. VALVE MARKER POSTS SHALL MEET THE SAME REQUIREMENTS AS SHOWN IN THE WATER DETAILS AND BE PAINTED AS SPECIFIED IN THE STANDARD CONSTRUCTION NOTES.
3. ALL DIP AND FITTING SHALL BE PROTECTOR 401 EPOXY COATED. ALL PIPE AND FITTINGS SHALL BE RESTRAINED JOINT.



TYPICAL SCHEMATIC PLAN VIEW

REVISIONS	AMERICAN WATER MILITARY SERVICES GROUP CIVIL SANITARY FORCE MAIN CLEANOUT DETAIL
6/13 - MSG EDITS	
1/16 - MSG EDITS	
	AMERICAN WATER MILITARY SERVICES GROUP CAMDEN, NJ 08102
	AMERICAN WATER M.S.G. 1 WATER STREET CAMDEN, NJ 08102
	 AMERICAN WATER.
	DRAWN BY PDK PROJECT ENG'R PDK APPROVED
	DATE 06-10-2013 PROJECT N/A
	USE APPROVED DRAWINGS ONLY FOR CONSTRUCTION PURPOSES
	USE DIMENSIONS ONLY SCALE N.T.S.
	MSG-WW-19

FINAL

MSG-W-19