

GIS Requirements

Water Main Construction Projects

The requirements and deliverables identified below are those for water main construction projects performed by Developers, Contractors, and Internal Illinois-American Water crews.

At a high level overview, the Resident Project Representative (RPR) is responsible for the following. These deliverables are to be submitted to the ILAWC Engineering Project Manager upon project completion or when the project is substantially complete.

1. Two copies of the final as-built plan set
 - One copy will be paper and the other copy will be electronic, in its native AutoCAD format (.dwg). The paper copy should include any mark-up captured during the final walk through. The paper copy can be scanned and provided as a PDF.
2. GPS data
 - Submitted in Shapefile format, along with the source/raw GPS data file (i.e., job or ssf file) and a horizontal accuracy report.
3. Equipment Data Spreadsheet

The above deliverables are to be provided as a zip file to your ILAWC Engineering Project Manager.

Each deliverable is explained in more detail below:

Final As-Built Plan Set

The RPR will submit two copies of the final as-built plan set. One copy will be paper and the other copy will be electronic, in its native AutoCAD format (.dwg). The paper copy should include any mark-up captured during the final walk through. The paper copy can be scanned and provided as a PDF.

1. The final as-built shall be the entire plan set in its native AutoCAD format (.dwg). It shall include, at a minimum, all detail pages, additional inclusions, and attribution as noted below:
 - Each new valve, hydrant, fitting, and, if applicable, corporation stop and meter pit, shall be annotated with the same temporary ID assigned to it for both the GPS point and the corresponding record within the Equipment Data Spreadsheet.
 - Water mains shall include:
 - Diameter
 - Material
 - Joint Type
 - Length between fitting(s), valve(s), start/end of encasement(s)/restraint(s), material change(s), and any other notable feature(s).
 - Exterior Protection (Yes/No)
 - If yes, note the type of exterior protection
 - Lined (Yes/No)

GIS Requirements

- If yes, note the Lining Material and Lining Method used.
 - Tracer Wire (Yes/No)
- If applicable, service lines shall include:
 - Type: Domestic, Hydrant Lateral, Fire, Irrigation, or Combined
 - Diameter
 - Material
 - Joint Type
 - Lined (Yes/No)
 - If yes, note the Lining Material and Lining Method used.
 - Exterior Protection (Yes/No)
 - If yes, note the type of exterior protection
 - Tracer Wire (Yes/No)
- Notes/details depicting assets that are to be retired. Please include whether the assets were abandoned in place or removed from the ground.
- Easements acquired, along with all relevant sketches and legal descriptions.
- Any and all field sketches that show variances from the design plan set.
- Detailed sketches depicting intersections and tie-ins.

GPS Data & the Equipment Data Spreadsheet

The Resident Project Representative (RPR) is responsible for collecting all GPS points for features and locations outlined below:

- The center of each fitting, valve, and hydrant
- Water mains at deflection points and every 100 ft along straight runs
- The location of each connection to existing facilities
- The corners of all easements being granted to the company as part of the project
- For projects that include the installation of service lines, GPS points will be required for all service line related corporation stops, valves (to include all curb stops), and/or meter pits, as well as any bends in between these features.
- Other locations as designated by the company

This data shall be collected after the piping and appurtenances are installed, but before the trench is backfilled. If it is decided to not collect GPS data while the trench is open, vertical riser pipes must be installed at each buried feature (i.e., valves, fittings, deflection points, etc...) and at every 100 ft along the water main to allow collection of the GPS point.

All new valves¹, hydrants, fittings, and, if applicable, corporation stops² and meter pits, shall have records created within the provided Illinois-American Water Equipment Data Spreadsheet. All fields are to be

1 For curb stops, complete a record within the Valves tab of the Equipment Data Spreadsheet.

2 For corporation stops, complete a record within the Fittings tab of the Equipment Data Spreadsheet.

GIS Requirements

populated. It is within this spreadsheet that the descriptive detail of each asset is captured (i.e., valve size, hydrant type, etc...).

Each GPS point collected shall be assigned a **unique** temporary ID and that **same** temporary ID shall be used within the Equipment Data Spreadsheet to allow for the association of point to record.

Suggested temporary IDs are:

- Valves: V1, V2, V3, etc...
- Hydrants: H1, H2, H3, etc...
- Fittings: F1, F2, F3, etc...
- Meter Pits: MP1, MP2, MP3, etc...
- Additional Data: AD1, AD2, AD3, etc...

General Collection Requirements are as follows:

1. At minimum, Sub-foot accuracy is required.
2. GPS point coordinates must be field collected. Point coordinates CANNOT be generated from AutoCAD or other similar application and converted to a Shapefile.
3. A benchmark GPS shot must be collected at the start of GPS data collection, as well as again at the end of GPS data collection.
 - If you **are not** using a real time processing solution and are post processing your data please collect a benchmark at the start of each week of collection.
 - **Benchmark requirements:**
 - Please use an NGS-listed benchmark. Nearby benchmarks can be located using the following web site: <http://www.ngs.noaa.gov/NGSDDataExplorer/>
 - Vertical only benchmarks are not allowed.

Setup/Collection Requirements are as follows:

1. The coordinate system **MUST** be defined as below:

For projects within our Alton, Cairo, Interurban, Lincoln, Pekin, Peoria, South Beloit, or Sterling service areas please use the following coordinate system definition:

- System: US State Plane NAD 1983
- Zone: Illinois West 1202
- If applicable, use the Geoid Model 12

For projects within our Champaign, Chicago Metro, Hardin County, Pontiac, or Streator service areas, please use the following coordinate system definition:

- System: US State Plane NAD 1983
- Zone: Illinois East 1201
- If applicable, use the Geoid Model 12

GIS Requirements

2. Please be mindful of the coordinate definitions when processing your data. Please do not ignore any warnings that the coordinate systems do not match.
 - For example, when bringing/opening job(s) in Trimble Business Center, be sure to define the coordinate system of your project to match the definition assigned to your job.

Output Requirements are as follows:

The following lists the items to be submitted, as well as defines the required properties of those items as it pertains to the collected GPS points.

1. Please export the collected data as a Shapefile.
2. Please run a report that documents, at minimum, the horizontal accuracy of each point.
3. Along with the exported output, as well as an accuracy report, please also return any/all source collection files (i.e., ssf, job, etc...)

GIS Project Deliverables – Delivery Requirements

Please place all GIS Project Deliverables within a named project folder. Zip this folder up and provide to your ILAWC Engineering Project Manager. Please see graphic below for requested structure.

GIS Deliverables Project Folder	IL_Alton_Golf_As_Built
Shapefile	IAWC GOLF - GIS SHAPEFILE.shp
<i>Note: The shapefile is a GIS data format that is composed of (at minimum) 4 files that have the same name with the extensions: dbf, prj, shp, and shx.</i>	Points.dbf Points.prj Points.shp Points.shx
<i>Please place your shapefile in its own folder within the GIS Deliverables Project Folder.</i>	
Equipment Data Spreadsheet	EquipmentData_Water_Golf_Alton_IL.xlsx
As-Built in AutoCAD format	IAWC (448385.0) WADLOW GOLF BASETOPO ASBUILT.dwg
GPS Data Accuracy Report	IAWC GOLF - QUALITY CONTROL REPORT.pdf
As-Built in PDF format *	IAWC GOLF IMPROVEMENTS (AS-BUILT) 2015-02-11.pdf
GPS Data Source Data File **	IAWC GOLF RD GIS.job

Questions

Please e-mail any questions to Shawn Simpson, GIS Project Manager, at shawn.simpson@amwater.com. Be sure to CC your Illinois-American Water Engineering Project manager, as well.

For your convenience, a checklist is provided.

GIS Requirements | Checklist

Project Name: _____
 District: _____
 In-Service Date: _____

Please check all boxes below that have been completed and have all unchecked boxes corrected.

GPS Points

- Did you collect all required benchmark shots?
- Did you collect shots on **all** Fittings?
- Did you collect shots on **all** Valves?
- Did you collect shots on **all** Hydrants?
- Did you collect shots every 100 feet along straight runs?
- Did you collect shots at **all** main deflection points (if applicable)
- Did you collect shots at **all** corners of all easements being granted to ILAW as part of the project (if applicable)
- Did you collect shots at **all** location(s) of each connection to existing facilities (if applicable)
- Did you collect shots at **all** other locations, as designated (If applicable, list other locations below):
- Did you collect shots on **all** Service line features (if applicable). To include all corporation stops, valves/curb stops, meter pits, and any bends in between.

Equipment Data Spreadsheet

- Do **all** fittings have records created within the project's Equipment Data Spreadsheet? **Correct IDs?**
- Do **all** valves have records created within the project's Equipment Data Spreadsheet? **Correct IDs?**
- Do **all** hydrants have records created within the project's Equipment Data Spreadsheet? **Correct IDs?**
- Do **all** meter pits have records created within the project's Equipment Data Spreadsheet? **Correct IDs?**
- Do **all** additional data shots have records created within the project's Equipment Data Spreadsheet? **Correct IDs?**

GIS Deliverables

- Do you have all required deliverables (i.e., Shapefile, source GPS data file, accuracy report, equipment data spreadsheet, and two copies of the final as-built plan set) zipped up in a GIS deliverable project folder?

As-Built Plan Set

- Two copies ready to submit? One being the electronic AutoCAD version and the other being the paper/PDF copy?
- Does the paper/PDF copy include all mark-ups?
- Are all features attributed with their correct temporary ID (i.e., V1, H1, F1, MP1, AD1)?

Are the following main attributes present:

- Material and Diameter
- Joint Type
- Length between fitting(s), valve(s), start/end of encasement(s)/restraint(s), material change(s), and/or any other notable feature(s)
- Exterior Protection (Yes/No); If "Yes", ensure the type of exterior protection is provided.
- Lined (Yes/No); If "Yes", ensure the lining material and lining method is provided.
- Tracer Wire (Yes/No)

If application, are the following service line attributes present:

- Type: Domestic, Hydrant Lateral, Fire, Irrigation, or Combined
- Material and Diameter
- Joint Type
- Exterior Protection (Yes/No); If "Yes", ensure the type of exterior protection is provided.
- Lined (Yes/No); If "Yes", ensure the lining material and lining method is provided.
- Tracer Wire (Yes/No)

If application, are the attributes/notes/details below present:

- Notes/details depicting assets to be retired (if applicable)
- All relevant Easement documentation?