



NOTES:

1. POLYETHYLENE ENCASMENT ON ALL DI AND BRASS PIPE.
2. SEE DWG. NO. 0201-0601-SD08 FOR RESTRAINT OF CAP.
3. CURB BOX FOR VALVE NOT SHOWN.
4. TO BE USED ON 6" AND SMALLER DEAD END MAINS AS SHOWN ON THE PLANS OR AS APPROVED BY THE ENGINEER.

REVISIONS

**MISSOURI AMERICAN WATER STANDARD
CIVIL
BLOWOFF / FLUSHING HYDRANT ASSEMBLY
DETAIL**

MISSOURI AMERICAN WATER
ST. LOUIS, MO. 63141

MISSOURI AMERICAN WATER ENGINEERING
727 CRAIG ROAD
ST. LOUIS, MO. 63141



AMERICAN WATER

DRAWN BY MEG
PROJECT ENG'R
APPROVED

DATE 11-30-18
PROJECT IP

USE DIMENSIONS ONLY
SCALE N.T.S.

USE APPROVED DRAWINGS ONLY
FOR CONSTRUCTION PURPOSES

0201-0601-SD01