



# Penns Grove

## Typical Water Quality Information

**PWSID Number:** NJ1707001

**Area Served:** Borough of Penns Grove, Carney’s Point Township, Pedricktown and Oldman’s Township in part

### Where Does My Water Come From?

7 wells that draw from the Potomac-Raritan-Magothy Aquifer and 1 treated surface water supply from the Delaware River

### Average amount of water supplied to customers on a daily basis

1.40 million gallons per day

Parameter	Average or Range	Comments
pH	7.45	pH is a measure of the acid/base properties of water.
Total Hardness (as CaCO <sub>3</sub> )	84 mg/L	Naturally occurring calcium/magnesium content in the water.
Total Hardness (as CaCO <sub>3</sub> )	5.32 grains per gallon	Naturally occurring calcium/magnesium content in the water.
Fluoride	0.40 mg/L	Naturally occurring from erosion of natural deposits, MCL = 4.0 mg/L
Sodium	90 mg/L	Naturally occurring from erosion of natural deposits. No MCL – Informational only
Iron	0.01 mg/L	Naturally occurring from erosion of natural deposits and water treatment chemicals Secondary Standard Limit = 0.3 mg/L

<b>Parameter</b>	<b>Average or Range</b>	<b>Comments</b>
Manganese	0.014 mg/L	Naturally occurring from erosion of natural deposits.
Type of disinfection	N/A	Chlorine
Disinfectant residual level in the distribution system	0.70 mg/L	Max Residual Disinfectant Level Running Annual Avg. = 4.0 mg/L
Lead [90 <sup>th</sup> percentile result]	2 ug/L	Corrosion of household plumbing; erosion of natural deposits. Action Level = 15 ug/L
Copper [90 <sup>th</sup> percentile result]	0.449 mg/L	Corrosion of household plumbing; erosion of natural deposits. Action Level = 1.3 mg/L
Nitrate	2.02 mg/L	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits. MCL = 10 mg/L
Arsenic	ND	MCL = 5 ug/L
Chromium-6	0.28 ug/L	Chromium-6 is not currently regulated as an individual contaminant. For more information, please visit <a href="http://www.amwater.com/njaw/Ensuring-Water-Quality/Chromium-6">http://www.amwater.com/njaw/Ensuring-Water-Quality/Chromium-6</a>

**Definitions**

- mg/L – milligrams per liter; one milligram per liter is equal to one part per million (ppm), which is approximately the same as 1 second in 11.5 days
- ug/L – micrograms per liter; one microgram per liter is equal to one part per billion (ppb), which is approximately the same as 1 second in 31.7 years
- N/A – not applicable
- ND – not detected
- MCL – Maximum Contaminant Level – the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the Water Quality Report located on the American Water web site

For more information about water quality in your area please contact our water quality staff at 856-764-4935

Other inquiries should be directed to our Customer Service Center at 1-800-652-6987