



Sherwood Forest

Typical Water Quality Information

PWSID Number: VA4133800

Area Served: Sherwood Forest (Zip Code: 22539)

Where Does My Water Come From?

The source of your drinking water is groundwater. The wells draw water from the Potomac aquifer.

Average amount of water supplied to customers on a daily basis

12,000 gallons per day

Parameter	Average or Range	Comments
pH	8.6	Measure of the acid/base properties of water
Fluoride	1.91 mg/L	Naturally occurring and water additive, MCL = 4.0 mg/L
Sodium	171.8 mg/L	Naturally occurring from erosion of natural deposits No MCL – Informational only
Iron	ND	Naturally occurring Secondary Standard Limit = 0.3 mg/L
Manganese	ND	Naturally occurring from erosion of natural deposits
Type of disinfection	N/A	chlorine
Disinfectant residual level in the distribution system	0.38 – 1.8 mg/L	Water additive to control microbes

Parameter	Average or Range	Comments
Lead [90 th percentile result]	ND	Corrosion of household plumbing; erosion of natural deposits Action Level = 15 ug/L
Copper [90 th percentile result]	0.114 mg/L	Corrosion of household plumbing; erosion of natural deposits Action Level = 1.3 mg/L
Alkalinity	312 mg/L	Natural calcium / magnesium content in the water
Hardness	2.5 mg/L	Ability of water to neutralize acid and bases and maintain a stable pH
Nitrate	ND	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits MCL = 10 mg/L
Arsenic	0.0015 mg/L	MCL = 0.010 mg/L

Definitions

- mg/L – milligrams per liter; one milligram per liter is equal to one part per million (ppm), which is approximately the same as 1 second in 11.5 days
- ug/L – micrograms per liter; one microgram per liter is equal to one part per billion (ppb), which is approximately the same as 1 second in 31.7 years
- N/A – not applicable
- ND – not detected
- MCL – Maximum Contaminant Level – the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the
Water Quality Report located at
<http://www.amwater.com/ccr/sherwoodforest.pdf>.

For more information on your water quality, please contact
Kelly Ryan, Water Quality Supervisor, at 804-446-9822

Other inquiries should be directed to our
Customer Service Center at 1-800-452-6863