



# South Hill Banks

## Typical Water Quality Information

**PWSID Number:** VA4057750

**Area Served:** South Hill Banks (Zip Code: 22437)

### Where Does My Water Come From?

The source of your drinking water is groundwater. The wells draw water from the Potomac aquifer.

### Average amount of water supplied to customers on a daily basis

3,700 gallons per day

Parameter	Average or Range	Comments
pH	7.95	pH is a measure of the acid / base properties of water
Fluoride	0.61 mg/L	Naturally occurring and water additive, MCL = 4.0 mg/L
Sodium	49.3 mg/L	Naturally occurring from erosion of natural deposits No MCL – Informational only
Iron	0.2 mg/L	Secondary Standard Limit = 0.3 mg/L
Manganese	ND	Naturally occurring from erosion of natural deposits
Type of disinfection	N/A	chlorine
Disinfectant residual level in the distribution system	0.68 – 1.66 mg/L	Water additive to control microbes

<b>Parameter</b>	<b>Average or Range</b>	<b>Comments</b>
Lead [90 <sup>th</sup> percentile result]	3.0 ug/L	Action Level = 15 ug/L
Copper [90 <sup>th</sup> percentile result]	0.062 mg/L	Action Level = 1.3 mg/L
Alkalinity	173 mg/L	Ability of water to neutralize acid and bases and maintain a stable pH
Hardness	74 mg/L	Natural calcium / magnesium content in the water
Nitrate	ND	MCL = 10 mg/L
Arsenic	ND	MCL = 10 ug/L

**Definitions**

- mg/L – milligrams per liter; one milligram per liter is equal to one part per million (ppm), which is approximately the same as 1 second in 11.5 days
- ug/L – micrograms per liter; one microgram per liter is equal to one part per billion (ppb), which is approximately the same as 1 second in 31.7 years
- N/A – not applicable
- ND – not detected
- MCL – Maximum Contaminant Level – the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the Water Quality Report located on the American Water web site.

[www.amwater.com/ccr/southhillbanks.pdf](http://www.amwater.com/ccr/southhillbanks.pdf)

For more information on your water quality, please contact Kelly Ryan, Water Quality Supervisor, at 804-446-9822

Other inquiries should be directed to our Customer Service Center at 1-800-452-6863