


FILE NO.	
INDEX NO.	
ISSUED DATE	08-2020
AMENDED DATE	

ALL PLUMBERS ARE REQUIRED TO BLOCK UNDER A NEWLY TAPPED SERVICE LINE AT POINT "A" IN THE DRAWING BELOW WHICH IS UNDER CORPORATION COCK.





NOTE: IN SOME CASES, WATER MAIN WILL BE ON OPPOSITE SIDE OF STREET

BLOCKING AT POINT "A" WILL ALLOW FOR MINOR SETTLEMENT OF EITHER THE SERVICE LINE OR THE NEW WATER MAIN AND STILL RETAIN SUPPORT FOR THE SERVICE LINE AND CORPORATION COCK DURING BACKFILLING OPERATIONS.

DRG. #SLB-.75>

WS 6.20

WATER SERVICES

SUBJECT TO REVISION WITHOUT NOTICE 08-08-2020

SERVICE LINE BLOCKING FOR 3/4" TO 2 1/2" SERVICES